

“smart” CHECK LIST©

Notes:

1. This document might be outdated. Check the header area for revision date. Please download the latest version at <http://www.byunpartners.com/Documents/checklist.pdf>
This document can also be found with following QR code.



Figure 1: QR code of this document, iPad friendly.


2. Please use this checklist to stimulate your thought. Add, delete, and revise as needed and submit to spec writer. By no means this check list has everything you need for your project. However, this check list should be completed prior to embarking on writing specification. Undoubtedly you will find items required for your project beyond this check list.
3. The specification describes in word “What” the product is. Drawings show “where” the product is used. Need to distinguish if the product has more than one variation. For example GL-1 and GL-2 for different types of glazing.
4. If the specification is to have any real value, project managers must have the opportunity to provide relevant project information to the specification writer.
5. Who should write the spec? If it is on consultants’ drawings, consultants should write it. If it says “See Architectural” then architectural drawings should detail this up and I will further elaborate on spec.
6. Stop. Read the whole documents before filling in the blank spaces.
7. Put question marks for items that are pending or not sure.
8. Again, not all items used in the project are in this lists. Feel free to add for your project.
9. Remember, we can’t be accurate if we are confused.
10. Sustainable Design: Product or product category with  a symbol in front indicates it contributes to one or more LEED, HPI, or CHPS credit category.
11. Before returning completed form back the spec writer, first have it reviewed by the project Architect of Record.
12. Section number are identified with CSI 2004 Format first and 1995 in parenthesis. 024119 (01732).
13. Short spec: Not recommended. Write full specs to get the maximum protection.
14. “smart” because you can look up listed products directly from this document by hyperlink (internet connection required).
15. Feel free to make any suggestions you might have to make this checklist a better tool.
16. This checklist is used for giving you an accurate spec fee proposal. Please be as complete as possible. More sections I need to write, higher the fee.
17. “People don’t want to buy a quarter-inch drill, they want a quarter-inch hole”. The checklist is a valuable listening tool for spec writer.
18. Spec writers are “generalist” (including me). I write 50 or more architectural sections per project and I don’t know everything. Don’t be afraid to seek help from the specific manufacturer. They are the “specialist” in their products.
19. I DO NOT know and I DO NOT pretend to know “door hardware”. Please hire a door hardware consultant.
20. I am really fast but I do attend seminars regularly and I will be out of the office. Please plan accordingly.
21. Do email manufacturer’s CSI 3-part specs if you have them. But, first edit them. I can’t choose options for you. You are the designer.
 - o Unless, you want me to pick options I like. (Not recommend). Same applies when you email me manuf cutsheets. Select all the options YOU like before emailing them to me.
22. Thank you, thank you, thank you.

Table of Contents

Categories	A. Waterproofing
	B. Structural Consultant
	C. Roofing
	D. Roof Accessories/Skylights
	E. Exterior
	F. Interior
	G. Ceiling - interior
	H. Walls - interior
	I. Floors - interior
	J. Tile
	K. Windows
	L. Doors
	M. Painting
	N. Stairs/Elevators
	O. Toilet Accessories
	P. Special Construction
	Q. Div 1 Sections
R. Rehabilitation of Historic Buildings	
S. Manufacturer's Contact Information	

Project Summary

Project Name	
Project Number	
Client Name	
PM/PA Name	
Scope of Work (Text for Section 01100)	Short summary. Best to be generic. Not too detailed where it becomes scope of work issue where it contradict drawings.
This project is very similar to previous project	Project number: _____ Project name: _____ <input type="checkbox"/> No similar project in the past.
Construction Type	<input type="checkbox"/> Design – Bid – Build (traditional) <input type="checkbox"/> Design – Build
Contract Type	<input type="checkbox"/> Lease – Lease Back
Construction Cost - estimated	\$ _____
Header information	Anything you want. (But make it short). Do not include phase or date (it will be in the spec cover)
Footer information	Reserved for section number, section title, and page. (Recommend not changing the footer at all)
Construction Administration	<input type="checkbox"/> by Architect <input type="checkbox"/> by Construction Manager <input type="checkbox"/> By Owner’s rep.
Submittal method during CA	Electronic: <input type="checkbox"/> Submittal Exchange <input type="checkbox"/> Email <input type="checkbox"/> Other____ <input type="checkbox"/> Paper based.
Architect of Record	Name: _____
CalGreen Code Applicable?	<input type="checkbox"/> Yes, follow this City code: _____ <input type="checkbox"/> No, because: _____
General Condition (GC)	<input type="checkbox"/> AIA A201 <input type="checkbox"/> Custom by Owner/District I need to see current (or at least previous project) GC to coordinate Div 1 sections.
Client Standards	<input type="checkbox"/> Preferred products (Need a copy w/project specific markup. Better than using the checklist) Incorporate products on the drawings as contractor will never see the client standards. <input type="checkbox"/> None.
Master	<input type="checkbox"/> Use client’s master (attached- electronic) <input type="checkbox"/> AIA Masterspec (Default) <input type="checkbox"/> SpecsIntact (military) <input type="checkbox"/> LAUSD <input type="checkbox"/> SDUSD <input type="checkbox"/> VA <input type="checkbox"/> Other _____
Spec Format	CSI 2004 format (6 digit section number). 49 divisions. – Default. Please note that CSI 1995 format (5 digit section number). 16 divisions. – No longer supported (AIA MasterSpec no longer updated).
Special Requirements	<input type="checkbox"/> USGBC - LEED , Level: _____ (Email score card) <input type="checkbox"/> CHPS <input type="checkbox"/> DSA <input type="checkbox"/> OSHPD <input type="checkbox"/> None.
Deferred Approvals	<input type="checkbox"/> Fire Sprinklers <input type="checkbox"/> Elevator <input type="checkbox"/> Other: _____ <input type="checkbox"/> None
Fire-Rated Assemblies	Fire-rated construction for Elec, Mech, and Storage Rooms: <input type="checkbox"/> Yes <input type="checkbox"/> No Fire-rated construction for Area Separations: <input type="checkbox"/> Yes <input type="checkbox"/> No All gypsum board will be Type X 5/8 inch regardless of fire-ratings required. Identify all fire-rated doors in the Door Schedule and fire-rated windows in the Window Schedule.
Building Type	<input type="checkbox"/> Type I <input type="checkbox"/> Type 3 <input type="checkbox"/> Type V <input type="checkbox"/> Type VB <input type="checkbox"/> Other: ____ <input type="checkbox"/> CMU <input type="checkbox"/> Concrete
Stud Framing	<input type="checkbox"/> Steel framing (sections 05400 by structural consultant & 09111 by Architect) <input type="checkbox"/> Wood framing (section 06100 by structural consultant)
Building	<input type="checkbox"/> Single story <input type="checkbox"/> Two stories <input type="checkbox"/> [] stories
Alternates (ALT)	<input type="checkbox"/> As indicated on Drawings <input type="checkbox"/> None <input type="checkbox"/> List:____ Definition: An amount proposed by bidders and stated on the Bid Form for certain work defined in the bidding requirements that may be added to or deducted from the base bid amount if Owner decides to accept a corresponding change either in the amount of construction to be completed or in the products, materials, equipment, systems, or installation methods specified.
Allowances (ALLOW)	<input type="checkbox"/> As indicated on Drawings <input type="checkbox"/> None <input type="checkbox"/> List:____ Types: <input type="checkbox"/> Lump-sum allowances. You have to specify the dollar amount. <input type="checkbox"/> Unit-cost allowances. (Also require unit price section)

	<input type="checkbox"/> Quantity allowances. (Also require unit price section) <input type="checkbox"/> Contingency allowances. <input type="checkbox"/> Testing and inspecting allowances.
Unit Price	<input type="checkbox"/> As indicated on Drawings <input type="checkbox"/> None <input type="checkbox"/> List: _____ Definition: Unit price is a price per unit of measurement for materials, equipment, or services, or a portion of the Work, added to or deducted from the Contract Sum by appropriate modification, if the scope of Work or estimated quantities of Work required by the Contract Documents are increased or decreased.
Units of Measure	<input type="checkbox"/> Inch, Feet/Pounds only (default) <input type="checkbox"/> Metric only <input type="checkbox"/> Both
Project Meeting Attendance by Architect	Required number of meetings _____ (provide copy of language) Scheduled visits required _____ (provide copy of language) *Verify with Owner/Architect Contract
Coordinate with Mechanical Consultant (for their energy calc)	<input type="checkbox"/> Fenestration: U-factor: _____ SHGC: _____ <input type="checkbox"/> Skylight: U-factor: _____ SHGC: _____ Insulation: (Identify on Drawings) Roof <input type="checkbox"/> R-30 <input type="checkbox"/> Other: _____ Exterior Walls <input type="checkbox"/> R-13 <input type="checkbox"/> R-19 <input type="checkbox"/> Other: _____
Project Team: NOTE: Creation of signature page and routing of it is not part of spec fee. Route them internally.	List only consultant that will be providing CSI 3-part specs here: <input type="checkbox"/> Civil: <input type="checkbox"/> LEED: _____ <input type="checkbox"/> Landscape: <input type="checkbox"/> CxA: _____ <input type="checkbox"/> Structural: <input type="checkbox"/> Mechanical: <input type="checkbox"/> Electrical: <input type="checkbox"/> Plumbing: Hardware: <input type="checkbox"/> Allegion (IRCO) <input type="checkbox"/> Assa Abloy <input type="checkbox"/> AHC (John Elmore) for fee. <input type="checkbox"/> Stanley <input type="checkbox"/> In-House <input type="checkbox"/> Communication: <input type="checkbox"/> Audio Visual: <input type="checkbox"/> Kitchen Equipment: <input type="checkbox"/> Interior Designer: Others: _____ Consultants Deliverables: All consultants providing CSI 3-part specifications shall email all spec sections in PDF. (Do NOT combine them into one file). Also provide their spec section Table of Contents. File naming convention: Section number space section title. i.e. 072010 Building Insulation (Do NOT put spaces between section numbers – 07 20 10)
Print Instructions	<input type="checkbox"/> Electronic (pdf, FTP) <input type="checkbox"/> Print Double Sided (default) <input type="checkbox"/> Print Single Sided
Font Type/Size	<input type="checkbox"/> Times New Roman/11 pt. (default) <input type="checkbox"/> Other: _____
Special Instructions	

Before returning completed form back the spec writer, first have it reviewed by the project Architect of Record.

DEMOLITION

Demolition	<input type="checkbox"/> Partial interior demolition - Selective Demo 024119 (01732). – Architectural. <input type="checkbox"/> Complete demolition of building - Building Demo 024116 (02221) – By Structural Engineer. <input type="checkbox"/> Site demolition. – By Civil engineer. <input type="checkbox"/> Abatement contractor – Separate contract. <input type="checkbox"/> Abatement is part of this contract – Need to cross-reference Abatement report.
-------------------	--

JOINT SEALANTS

Sealants	<input type="checkbox"/> Through-penetration firestop - 078413 (07841). <input type="checkbox"/> Fire-resistive joints - 078446 (07841). Standard - 079200 (07920). Application: <input type="checkbox"/> Interior <input type="checkbox"/> Exterior Substrates: <input type="checkbox"/> Metal <input type="checkbox"/> Wood <input type="checkbox"/> Gypsum <input type="checkbox"/> Other: _____
-----------------	---

WATERPROOFING

<p>Foundation Prep (Soils report should be reviewed for recommendations)</p>	<p>Underslab Vapor Barrier – 033005 (07113): Manufacturers: <input type="checkbox"/> Stego 15 mil <input type="checkbox"/> Perminator WR Meadow <input type="checkbox"/> Other: _____ 15 mil sheet, Class A (default): <input type="checkbox"/> By Structural (default). <input type="checkbox"/> By Architect * ASTM E 1745 sets three performance classes for plastic water-vapor retarders: Classes A, B, and C. The maximum water-vapor Permeance value of 0.3 perms is the same for each class. Two durability tests differentiate each class. Class A sets the highest, and Class C the lowest, tensile strength and puncture-resistance requirements. Neither thickness nor type of plastic is governed by ASTM E 1745.</p>
<p>Waterproofing - 071326 (07131) [Normally for below grade]</p>	<p>Dampproofing - 071113 (07115): Fluid applied to footing etc. <input type="checkbox"/> Sealmastic Type II Fibered by W.R. Meadows. <input type="checkbox"/> Other: _____</p> <p>Vertical Application: <input type="checkbox"/> Self-adhering sheet waterproofing (Bituthene 3000 by Grace) with drainage mat and then back-fill. <input type="checkbox"/> Blind-side - drainage mat and sheet waterproofing (Preprufe 160R HDPE by Grace). Drainage Panel: <input type="checkbox"/> Hydroduct 220 by Grace. Perimeter Drain: <input type="checkbox"/> Hydroduct Coil 600 by Grace. <input type="checkbox"/> Plumbing pipe by civil.</p> <p>Horizontal Application: <input type="checkbox"/> Between slabs: Sheet waterproofing. (Bituthene 3000 by Grace) <input type="checkbox"/> Foundation below slab: Upside-down Preprufe 300 HDPE in water table. (3x \$ Florprufe) <input type="checkbox"/> Foundation below slab: Florprufe 120. (21 mil, more of vapor barrier).</p>

STRUCTURAL CONSULTANT (coordination)





Best to have separate sections for structural vs architectural (it is usually more convenient to segregate requirements for structural and architectural into a separate Section; not to over-write each other).


<p>Cast-In-Place Concrete - 033000 (03300),- by Structural</p>	<p>Only structural items specified here by structural engineer. Non-structural items should be included as “default” in case there is no “Architectural concrete finishing” companion section. This section should cover: Cast-in-place, normal-weight and structural lightweight concrete for general building construction including related formwork, steel and fiber reinforcement, concrete materials and admixtures, vapor retarders, concrete mixture requirements, placement, as-cast and applied finishes, curing, and field quality control.</p>
<p>Architectural Concrete Finishing – 033500 - by Architect</p>	<p>This section “supplements” Cast-in-place concrete” to specify anything non-structural. Architectural Forms: <input type="checkbox"/> Special form-facing materials <input type="checkbox"/> Special form liners Architectural Aggregates: <input type="checkbox"/> Special aggregates Integral color admixture: Color: _____ <input type="checkbox"/> Chameleon by Davis Color. <input type="checkbox"/> Chromix by L.M. Scofieldx. <input type="checkbox"/> Chem-Masters Exposee H. Concrete Finishes: <input type="checkbox"/> Sacking. <input type="checkbox"/> Rubbed finish. <input type="checkbox"/> Steel Trowel finish. <input type="checkbox"/> Float finish. <input type="checkbox"/> Fine- Broom Finish <input type="checkbox"/> Broom Finish (default walkway finish for DSA projects) <input type="checkbox"/> Rough slab finish. Decorative: <input type="checkbox"/> Stamped (paver look) <input type="checkbox"/> Bushhammer finish. (surfaces are produced by pneumatic tools) <input type="checkbox"/> Match Architect’s sample. <input type="checkbox"/> Other: _____</p>
<p>034100 Precast Structural Concrete – 034100 - by structural</p>	<p>Only structural items specified here by structural engineer. This Section specifies precast, conventionally reinforced and prestressed, structural concrete units with standard commercial structural finishes as well as commercial architectural finishes, thinbrick facings, and stone facings. Flat-wall, precast structural concrete panels that are insulated are also included.</p>
<p>Precast Architectural Concrete – 034500 – by Architect</p>	<p>This section “supplements” Precast Structural Concrete” to specify anything non-structural. <input type="checkbox"/> Architectural finishes <input type="checkbox"/> Thinbrick facings <input type="checkbox"/> Stone facings. <input type="checkbox"/> Precast structural concrete panels that are insulated <input type="checkbox"/> Other: _____</p>
<p>Concrete Unit Masonry - - 042200 -by structural</p>	<p>Only structural items specified here by structural engineer. Section specifies single-wythe, concrete unit masonry for load-bearing and non-load-bearing applications. Precision CMU should be default.</p>
<p>Unit Masonry Finishes – 042211 -by Architect</p>	<p>This section “supplements” Unit Masonry” to specify anything non-structural. <input type="checkbox"/> Integral colored CMU. <input type="checkbox"/> Integral water repellents – DryBlock by WR Grace. <input type="checkbox"/> Clear sealer. – applied in the field.</p>

	<input type="checkbox"/> Split faced CMU <input type="checkbox"/> Factory shotblast CMU. <input type="checkbox"/> Field sandblast CMU. <input type="checkbox"/> Other: _____
Structural Steel – by Structural	<input type="checkbox"/> Structural Steel - 051200 (05120) <input type="checkbox"/> None. <input type="checkbox"/> Exterior Cold-form - 054000 (05400) - by structural consultant <input type="checkbox"/> Interior metal studs - 092216 (09111) by Architect
051213 – Architecturally Exposed Structural Steel (AESS) Framing – 051213 – by Architect	AESS Levels: <input type="checkbox"/> AESS 1: Structural Steel designated as “AESS 1 in the contract documents and conforming to ANSI/AISC 303-16, Chapter 10 definition of AESS1. These are basic elements with workmanship requirements exceeding those in non AESS construction. <input type="checkbox"/> AESS 2: Structural Steel designated as “AESS 2 in the contract documents and conforming to ANSI/AISC 303-16, Chapter 10 definition of AESS2. These are feature elements viewed at a distance greater than 20 feet. The art of metalworking is intended to be visible to the viewer. <input type="checkbox"/> AESS 3 (default): Structural Steel designated as “AESS 3 in the contract documents and conforming to ANSI/AISC 303-16, Chapter 10 definition of AESS3. These are feature elements viewed at a distance less than 20 feet. The art of metalworking is intended to be visible to the viewer. <input type="checkbox"/> AESS 4: Structural Steel designated as “AESS 4 in the contract documents and conforming to ANSI/AISC 303-16, Chapter 10 definition of AESS4. These are showcase elements with special surface and edge treatment beyond fabrication. The intent is the form is the only feature showing in an element. <input type="checkbox"/> AESS C: Structural Steel designated as “AESS C in the contract documents and conforming to ANSI/AISC 303-16, Chapter 10 definition of AESS C. These are custom AESS elements with characteristics described in the contract documents. AESS normally gets field coating of High Performance Coatings – See Section 099600 High-Performance Coatings.
Steel Decking - -053100 -by structural	Only structural items specified here by structural engineer. Section specifies structural steel deck.
Architectural Deck System – 053123 -by Architect	This section “supplements” Steel Decking” to specify anything non-structural. Architecturally Exposed - Decorative type by Epic: <input type="checkbox"/> Epicore ER2RA , acoustical, NRC 0.95. <input type="checkbox"/> Epicore 3.5A by Epic <input type="checkbox"/> New Millennium. <input type="checkbox"/> Other: _____
Rough Carpentry -061000 -by structural	Only structural items specified here by structural engineer. Section specifies wood framing.
Miscellaneous Rough Carpentry– 061053 -by Architect	This section is used for metal framed building where Rough Carpentry section is not used. <input type="checkbox"/> Rooftop equipment bases and support curbs. <input type="checkbox"/> Wood blocking and nailers. <input type="checkbox"/> Plywood backing panels. <input type="checkbox"/> Other: _____

ROOFING

Huge Disclaimer: Roofing/Waterproofing Systems are specialized assemblies that are beyond my expertise. Please contact your favorite manufacturer and seek help with specs and drawing details. Do not design them in a vacuum (you will have change orders). Have the manufacturer’s rep edit their standard spec for your project. I can’t edit their spec (again, you will have change orders if you have me edit).

<p>Roofing Fire: <input type="checkbox"/> (UL Class A) Wind: <input type="checkbox"/> I-75 Factory Mutual (FM): <input type="checkbox"/></p>	<p>Slope Type: Low (flat) Roofs: Single-Ply 075419 (07540) Thermoplastic Membrane Roofing  <input type="checkbox"/> Sarnafil - default, <input type="checkbox"/> Cool Zone by Duro-last <input type="checkbox"/> Sure-Flex by Carlisle Attach membrane: <input type="checkbox"/> Adhesively (G410 Sarnafil)-feltback to densdeck (default) concrete, wood, metal deck. <input type="checkbox"/> Mechanically (S327 Sarnafil) - with plates for wood or metal deck.</p>
	<p>Slope Type: Low (flat) Roofs: Built-up <input type="checkbox"/> 075113 (07511) Built-Up Asphalt Roofing (GAF, Tremco) Roof Deck (check Structural dwg.): <input type="checkbox"/> Sloped to drain <input type="checkbox"/> Not sloped (Need tapered insulation). <input type="checkbox"/> 1/4 inch (default, per code) <input type="checkbox"/> 1/2 inch. Roof Deck Type: (Ask for taper board plan in advance from Sarnafil) <input type="checkbox"/> Metal Deck <input type="checkbox"/> Structural Concrete Deck <input type="checkbox"/> Light Weight Concrete Deck <input type="checkbox"/> Plywood Deck</p>
	<p>Slope Type: Sloped Roofs: Metal Roofing Metal Roof Panels 074113 (07411) - (min 24 gage): <input type="checkbox"/>  metal soffit panels Product selection depends on roof slope and substrate. See AEP-Span literature for various slope recommendations. Slope: <input type="checkbox"/> 3:12 (watershed) <input type="checkbox"/> 1:12 (watershed) <input type="checkbox"/> 1/4:12 (watertight) Type/Substrate: <input type="checkbox"/> Architectural/Solid deck <input type="checkbox"/> Structural/Open frame - capable of spanning between supports. <input type="checkbox"/> 16" Select Seam Narrow Batten non-structural by AEP Span. <input type="checkbox"/> 16-1/2" Craftsman Series non-structural by MBCI. <input type="checkbox"/> 24" Snap-Seam structural batten by AEP Span.</p>
	<p>Slope Type: Sloped roofs: Asphalt Roofing Asphalt Shingles 073113 (07311)  <input type="checkbox"/> Timberline Color Series by GAF. <input type="checkbox"/> Landmark Shingles by CertainTeed. Underlayment: <input type="checkbox"/> Ice and Water Shield by Grace for critical areas.</p>
	<p>Slope Type: Sloped roofs: Clay Roof Tiles 073213 (07321) Profile: <input type="checkbox"/> Mission 2000 two-piece by Redland <input type="checkbox"/> Other: _____ Underlayment: Ice and Water Shield by Grace for critical areas.</p>
<p>Soffit</p>	<p><input type="checkbox"/> As exposed <input type="checkbox"/> Metal Panel <input type="checkbox"/> Portland cement plaster <input type="checkbox"/> None</p>
<p>Ridge Vents</p>	<p><input type="checkbox"/> Needed <input type="checkbox"/> Not needed (no sloped roof)</p>
<p>Integral Thermal Insulation w/ Roofing</p>	<p>Indicate R value on Drawings. Roof: <input type="checkbox"/> R-30 <input type="checkbox"/> Other: R- Insulation: <input type="checkbox"/> Rigid type over metal deck (default, 5 to 6 inches.) <input type="checkbox"/> Batt insulation from ceiling side (10 inches for R-30) <input type="checkbox"/> Remodel - Use existing insulation.</p>
<p>Building Insulation - 072100 (07210) Batt insulation thickness: R-11, 13: 3-1/2 inch thick. R-19: 6-1/4 inch thick. R-30:10 inches.</p>	<p>Indicate R value on <input type="checkbox"/> Drawings (default) <input type="checkbox"/> Specs (not recommended). Batt insulation: <input type="checkbox"/> Walls. <input type="checkbox"/> Ceiling, attached to deck. <input type="checkbox"/> Sound insulation (R-11). <input type="checkbox"/> Sprayed-sound insulation (K-13), integral color. Continuous insulation (rigid foam on exterior side): <input type="checkbox"/> 2 inch <input type="checkbox"/> _____ Exterior Wall: <input type="checkbox"/> R-19 <input type="checkbox"/> Other: R- _____ Interior partitions: <input type="checkbox"/> R-11 <input type="checkbox"/> R-19 (for sound) <input type="checkbox"/> Other: R- _____ Spray foam insulation: <input type="checkbox"/> R-value of 6.75 per inch, ICYNENE MD-C-200,  Rigid Insulation: <input type="checkbox"/> Wall – Z mate Rigid insulation with Z metal furring channels. <input type="checkbox"/> Remodel - Use existing insulation.</p>

	<input type="checkbox"/> Recycled jeans  See roofing for insulation integral part of roofing system.
Coping for Parapet	<input type="checkbox"/> Metal, integral with roofing (verify with roof manufacturer) <input type="checkbox"/> Metal, factory manufactured, Section - 077100 (07710) Manufactured Roof Specialties. <input type="checkbox"/> Portland Cement Plaster. <input type="checkbox"/> Other: _____ <input type="checkbox"/> Flexible flashing - 076500 (07650) underneath metal coping, door and wall Openings (Vycor Plus by Grace).
Fascia without Parapet	<input type="checkbox"/> Integral with roofing (verify with roofing manufacturer). <input type="checkbox"/> Factory manufactured. <input type="checkbox"/> Other: _____
Scupper, Downspout, Downspout Boot, Splash Block	Scuppers: <input type="checkbox"/> Scupper only at parapet. <input type="checkbox"/> Scupper, leader, downspout. Gutters: Shape: As indicated on Drawings. Type: <input type="checkbox"/> Hanging <input type="checkbox"/> Box/Built-in (internal, not exposed to view). Specified in: <input type="checkbox"/> Integral with metal roofing (match metal roofing). Sheet metal - 076200 (07620): <input type="checkbox"/> Galv steel <input type="checkbox"/> copper. Extra: <input type="checkbox"/> Wire mesh cover to protect from leaves <input type="checkbox"/> Strainer to prevent clogging. Downspout Material: <input type="checkbox"/> Schedule 40 black pipes (show diameter on dwg.). Sheet metal - 076200 (07620): <input type="checkbox"/> Galv steel <input type="checkbox"/> copper. Location: <input type="checkbox"/> Internal (not exposed to view) pipe by plumbing consult. <input type="checkbox"/> Exposed. Termination: <input type="checkbox"/> Tied to perimeter drain (Civil). Splash block: <input type="checkbox"/> Downspout, and boot (elbow). <input type="checkbox"/> Internal pipe (Civil), and boot (elbow).
Roofing	<input type="checkbox"/> New Roofing <input type="checkbox"/> Re-Roofing <input type="checkbox"/> Patch and repair
Re-Roofing	<input type="checkbox"/> Complete tear off - including roof deck. <input type="checkbox"/> Tear off - not including roof deck. <input type="checkbox"/> Other: _____
Patch and Repair	<input type="checkbox"/> Because roof is leaking. <input type="checkbox"/> Because roof equipment require patching. <input type="checkbox"/> Other: _____

ROOF ACCESSORIES/SKYLIGHTS

<p>Skylights <input type="checkbox"/> on flat roof <input type="checkbox"/> on slope roof <input type="checkbox"/> on ridge</p>	<p>Unit (factory unit) - 086200 (08620): Bristolite: <input type="checkbox"/> GAL (insulated glazing) <input type="checkbox"/> AL-CM: <input type="checkbox"/> acrylic single dome <input type="checkbox"/> acrylic double dome Velux: <input type="checkbox"/> FCM (fixed, site-built curb mount for 0 to 60 degree slope) Other: _____ Glazing: <input type="checkbox"/> Acrylic <input type="checkbox"/> Glass <input type="checkbox"/> Polycarbonate <input type="checkbox"/> Kalwall Aluminum Frame: <input type="checkbox"/> clear anodized <input type="checkbox"/> color anodized <input type="checkbox"/> Kynar Operations: <input type="checkbox"/> Fixed <input type="checkbox"/> Operable - manual <input type="checkbox"/> Operable - electric. Shapes: <input type="checkbox"/> Dome <input type="checkbox"/> Pyramid <input type="checkbox"/> As indicated. Curb (8 inch min height for flat roof): <input type="checkbox"/> Site built <input type="checkbox"/> Integral with skylight (not recommended, prone to leaks) Size: <input type="checkbox"/> As indicated on dwg (standard size from mfg.) <input type="checkbox"/> Custom size</p>
<p>Tubular Skylights – 086210 (08625)</p>	<p>Metal Framed (site fabricated) - 086300 (08630): <input type="checkbox"/> US Aluminum /CRL <input type="checkbox"/> Kawneer <input type="checkbox"/> Other: _____ <input type="checkbox"/> Rafter <input type="checkbox"/> Perlin Glass: <input type="checkbox"/> Laminated <input type="checkbox"/> Insulated <input type="checkbox"/> Tinted glass <input type="checkbox"/> Acrylic Frame: <input type="checkbox"/> Aluminum Cap Aluminum Frame: <input type="checkbox"/> clear anodized <input type="checkbox"/> color anodized <input type="checkbox"/> Kynar Operations: <input type="checkbox"/> Fixed <input type="checkbox"/> Operable - manual <input type="checkbox"/> Operable - electric. <input type="checkbox"/> Solatube <input type="checkbox"/> Tru-lite <input type="checkbox"/> SunTunnel by Velux <input type="checkbox"/> Other: _____</p>
<p>Photovoltaics – 136100 (13600)</p>	<p>Total Wattage: _____ Physical size: <input type="checkbox"/> As indicated on Dwg. <input type="checkbox"/> Battery backup <input type="checkbox"/> Net metering. Location: <input type="checkbox"/> low-sloped roof <input type="checkbox"/> sloped roof <input type="checkbox"/> Sun shade <input type="checkbox"/> on ground.</p>
<p>Roof Accessories - 077200 (07720)</p>	<p>Aluminum vertical ladder access specified in 055134 (05501). Access hatch with ladder safety post: <input type="checkbox"/> Type S by Bilco. Size as indicated. Other: _____ Smoke Vents (lets smoke out during fire): <input type="checkbox"/> Galv steel <input type="checkbox"/> Acoustical STC 45 <input type="checkbox"/> Lumivent, polycarbonate skylight by Bilco. Gravity Relief Ventilators: <input type="checkbox"/> Greenheck Model GRS. Other: _____ <input type="checkbox"/> Roof Curbs: Do not act as structural members. Used to support lighter loads such as packaged air-handling units. (<input type="checkbox"/> Site Built <input type="checkbox"/> Manufactured Unit) <input type="checkbox"/> Equipment Supports: Act as structural members. Used to support heavier loads such as larger custom air-handling units. (By structural consultant) <input type="checkbox"/> Equipment Isolators. (By Structural consultant)</p>
<p>Roof Access Ladder: can be either site fabricated by iron worker(055000) or manufactured item (055134)</p>	<p>055000 (05500) Metal Fabrications: <input type="checkbox"/> Field painted steel, galvanized exterior. (Default) <input type="checkbox"/> Other: _____ 055134 Aluminum ladders: <input type="checkbox"/> Vertical – O’Keeffe Model 501. <input type="checkbox"/> Vertical - Sure Step Model CL (Channel Ladder) by Royalite. <input type="checkbox"/> Over the parapet ladders - O’Keeffe Model 522. Interior Type: <input type="checkbox"/> 90 degree vertical <input type="checkbox"/> Incline Exterior Type: <input type="checkbox"/> 90 degree vertical <input type="checkbox"/> Incline <input type="checkbox"/> Vertical w/ over parapet. <input type="checkbox"/> Fall-protection cage (surrounding the ladder). <input type="checkbox"/> Security Door (lockable to deter access to ladder) – O’Keeffe accessories. <input type="checkbox"/> Attic access pull-down ladders - Model SS/AL-by Precision Ladders (Super Simplex).</p>
<p>Louvers and Vents - 089000 (10200)</p>	<p><input type="checkbox"/> Aluminum Storm Louvers by C/S Specialties. <input type="checkbox"/> #413-SXP (galvanized steel) non-drainable, 4 inch deep by Industrial Louvers. <input type="checkbox"/> #450XP would be same as #413SXP but in aluminum. <input type="checkbox"/> #258 (aluminum, not available in galvanized steel), drainable by Industrial Louvers. <input type="checkbox"/> K609HP, clear anodized by AiroLite. Finish: <input type="checkbox"/> Factory powder coat (recommended) <input type="checkbox"/> Field painted.</p>
<p>Equipment Screens –</p>	<p><input type="checkbox"/> Envisor by Cityscapes <input type="checkbox"/> Marquee II by McElroy <input type="checkbox"/> Other: _____</p>

074223 (07413)	<input type="checkbox"/> Custom grille work. <input type="checkbox"/> Portland cement plaster <input type="checkbox"/> Site fabricate from metal wall panels and channels.
-----------------------	---


EXTERIOR

CMU	Unit Masonry Finishes - 042011 (04811) (Exterior side) - also could be specified in structural consultant's Masonry spec section. <input type="checkbox"/> Painted CMU finish - 099100 (09910). <input type="checkbox"/> Sealed CMU finish - 042011 (04811), light- sand blast prior to sealing CMU. (Just cleaning doesn't quite do the job.) <input type="checkbox"/> Anti-Graffiti CMU finish - 099623 (09966) <input type="checkbox"/> Glazed block. <input type="checkbox"/> Glass block. Plaster Finish: <input type="checkbox"/> Plaster directly on CMU for site wall. <input type="checkbox"/> Plaster over metal lath and building paper on CMU for occupied spaces)
Stone Masonry – 044300 (04860)	Natural stones Stone Type: <input type="checkbox"/> Santa Barbara Sandstone <input type="checkbox"/> Granite <input type="checkbox"/> Lime Stone <input type="checkbox"/> Other: Attachment Method: <input type="checkbox"/> Adhered <input type="checkbox"/> Anchored Frame work: <input type="checkbox"/> CMU <input type="checkbox"/> Concrete <input type="checkbox"/> Stud <input type="checkbox"/> Other: _____
Brick Masonry 042113 (04210)	Brick Type: <input type="checkbox"/> Modular <input type="checkbox"/> Standard <input type="checkbox"/> Norman <input type="checkbox"/> Commercial Jumbo <input type="checkbox"/> Jumbo Method 1: Brick over solid: <input type="checkbox"/> Concrete <input type="checkbox"/> CMU <input type="checkbox"/> Plywood <input type="checkbox"/> Dens-Glass Method 2: Two layers of brick with air gap (cavity).
Manufactured Stone Veneer Assemblies - 047310 (04861)	Man-made stones <input type="checkbox"/> El Dorado Stones <input type="checkbox"/> Cultured Stone by Boral <input type="checkbox"/> Coronado Name and Color: _____ Frame work: <input type="checkbox"/> CMU <input type="checkbox"/> Concrete <input type="checkbox"/> Stud <input type="checkbox"/> Other: _____ Attachment: <input type="checkbox"/> Adhered <input type="checkbox"/> Anchored Trims: <input type="checkbox"/> Window sill stone. <input type="checkbox"/> Cap stone
Thin Brick Veneer – 042114 (04814)	<input type="checkbox"/> Think Brick: 1/2 x 2-1/2 x 8 inches by H.C. Muddox <input type="checkbox"/> Method: Adhered to exterior sheathing of wood-framed exterior walls.
Framing	Structural: <input type="checkbox"/> Steel Stud - 054000 (05400). <input type="checkbox"/> Wood Studs - 061000 (06100). Non-Structural: <input type="checkbox"/> Non-load bearing steel framing - 092216 (09111). <input type="checkbox"/> Miscellaneous Carpentry - 061053 (06105).
Portland Cement Plaster (Stucco) - 092400 (09220)	Backing: <input type="checkbox"/> Plywood Sheathing - 061000 (06100) by structural. <input type="checkbox"/> Glass-mat gypsum sheathing (GP DensGlass) – Sheathing 061600 (06160) <input type="checkbox"/> Metal lath and Building paper. <input type="checkbox"/> Finish Texture: _____ <input type="checkbox"/> Integral color only <input type="checkbox"/> Integral color and field painted (looks nice but field painting is not recommended, voids warranty on plaster finish). <input type="checkbox"/> Patch and repair only for remodeling. Soffit: <input type="checkbox"/> Exposed. <input type="checkbox"/> Prestige by AEP Span (metal <input type="checkbox"/> solid or <input type="checkbox"/> perforated). Metal Trim: Zinc-Coated (Galvanized) Steel (default). <input type="checkbox"/> Special Aluminum Reveals (Fry Reglet , need to note model on drawings)
EIFS – 072419 (07241)	<input type="checkbox"/> System with water drainage.
Metal Wall Panels - 074113 (07412)	<input type="checkbox"/> CS-200, concealed aluminum, Concept Series by Centria. <input type="checkbox"/> Flat - Model IW-10A by Centria. <input type="checkbox"/> Corrugated, Mini-V-Beam profile in 4-9/16" wide panels; lapped edges by AEP-Span. <input type="checkbox"/> Belvedere Rib Panel System, BWR360 by ATAS. <input type="checkbox"/> Flexbeam by Flexospan. Finish: <input type="checkbox"/> Solid factory Kynar coated galvanized steel. Perforated metal panels: <input type="checkbox"/> Kynar gal. steel <input type="checkbox"/> Aluminum <input type="checkbox"/> Stainless steel <input type="checkbox"/> Matching soffit panels. <input type="checkbox"/> Thermal batt insulation between studs from interior side.
Siding - 074600 (07460)	James Hardie

	<input type="checkbox"/> Vertical Siding <input type="checkbox"/> Lap Siding <input type="checkbox"/> American Fiber Cement <input type="checkbox"/> TruExterior by Boral <input type="checkbox"/> CeraClad <input type="checkbox"/> Other: _____ Substrates: <input type="checkbox"/> Plywood and moisture barrier <input type="checkbox"/> CMU <input type="checkbox"/> Other: _____
Exterior covered walkway	Material: <input type="checkbox"/> Metal Roof Panel <input type="checkbox"/> Same as Metal Roof Panel. <input type="checkbox"/> Other: _____
Sun Shade Devices	Fixed Sun Screens – 107113 (10711) Coordinate with windows and storefronts. <input type="checkbox"/> Sun Shade integral with Series 2600 Window by EFCO . <input type="checkbox"/> 20" tapered section by EFCO . <input type="checkbox"/> Model ST Series by Industrial Louvers , Kynar 2-coat finish. <input type="checkbox"/> 8" Airfoil and 1-1/2 x 12 inch box outrigger by C/S . Other: _____
Trellis panels – 108200 (10820)	<input type="checkbox"/> Greenscreen <input type="checkbox"/> CableRail by Feeney <input type="checkbox"/> Other: _____
Trellis walkway 06151	Need to detail on Drawings. <input type="checkbox"/> Cedar <input type="checkbox"/> Redwood <input type="checkbox"/> Pressure treated wood <input type="checkbox"/> Composite wood (see below) <input type="checkbox"/> Other: _____
Composite Wood – 065114 (06512)	<input type="checkbox"/> Trex <input type="checkbox"/> Nexwood <input type="checkbox"/> Eon <input type="checkbox"/> TimberTech <input type="checkbox"/> Resysta <input type="checkbox"/> Other: _____ These are combustible. Can't be used in Type I construction. Application: <input type="checkbox"/> Deck <input type="checkbox"/> Exterior decorative item
Awnings – 107313 (10531)	Awning is framed fabric extension projecting from and affixed to structure. Unlike canopies, awnings have no supporting ground poles. Unlike rectangular-shaped marquees that are supported by exposed rigid poles from above, awning fabrics incorporate and cover over any supporting framework and they are not limited to two dimensions. Type: <input type="checkbox"/> Fixed awnings. Retractable awnings: <input type="checkbox"/> Manually operated <input type="checkbox"/> Motorized. Fabric Material: <input type="checkbox"/> Glen Raven-Sunbrella <input type="checkbox"/> firesist HUV by Glen Raven-Sunbrella (fire-retardant). <input type="checkbox"/> Weathertyte Lite by Tri Vantage. (fire-retardant) <input type="checkbox"/> Other: _____ Metal frame: <input type="checkbox"/> Wrought iron <input type="checkbox"/> Aluminum <input type="checkbox"/> Other: _____
Canopy - 107316 (10533)	Basis of Design: _____ <input type="checkbox"/> Custom, coordinate with structural. <input type="checkbox"/> Tempered glass. <input type="checkbox"/> Stainless steel cables. Skin: <input type="checkbox"/> Painted galvanized steel. <input type="checkbox"/> Aluminum <input type="checkbox"/> Stainless steel Finishes: _____
Theater Marquee 10437	<input type="checkbox"/> Theater Marquee
Unit Pavers – 321316 (02780)	Basis of Design: <input type="checkbox"/> Concrete. <input type="checkbox"/> Brick. Installation: <input type="checkbox"/> Sand bed <input type="checkbox"/> Mortar bed. Edging Options: <input type="checkbox"/> Precast <input type="checkbox"/> Cast-In-Place.
Site Paving	Asphalt Paving – 321216 (02741) <input type="checkbox"/> Normally specified by Civil Consultant Concrete pavement – 321313 (02751) <input type="checkbox"/> Normally specified by Civil Consultant Pavement Marking 02752 <input type="checkbox"/> By Civil consultant. <input type="checkbox"/> By Architect. Detectable Warning Surfaces 02753 <input type="checkbox"/> By Civil consultant. <input type="checkbox"/> By Architect.
Porous Paving	<input type="checkbox"/> Porous Unit Paving – 321443 (02781) <input type="checkbox"/> Porous Site-Cast Paving -
Exterior Signs	Signage – 101400 (10431) <input type="checkbox"/> Building name/number signs <input type="checkbox"/> Parking signs. (Symbols of accessibility, accessible direction, etc.) <input type="checkbox"/> Traffic signs. (Stop, Yield, Do Not Enter, etc.).
Fences and Gates	<input type="checkbox"/> Temporary fencing during construction only - 015000 (01500)

	<p>Chain-Link Fences and Gates – 323113 (02821) Finish: <input type="checkbox"/> Galvanized <input type="checkbox"/> PVC over galvanized. Fences: <input type="checkbox"/> 9 gage (standard industrial) <input type="checkbox"/> 6 gage (heavy industrial). Gates: <input type="checkbox"/> Manual <input type="checkbox"/> Motorized. <input type="checkbox"/> Swing <input type="checkbox"/> Sliding: <input type="checkbox"/> Cantilevered <input type="checkbox"/> Overhead <input type="checkbox"/> Floor Track. Accessories: <input type="checkbox"/> Privacy slats <input type="checkbox"/> Wind screens.</p>
	<p>Ornamental Metal Fences and Gates – 323119 (02826) Fences: Ameristar: <input type="checkbox"/> Montage Plus <input type="checkbox"/> Aegis II <input type="checkbox"/> Montage II Master Halco: <input type="checkbox"/> Classic Premier. Ametco: <input type="checkbox"/> Shadow 100. Gates: <input type="checkbox"/> Manual <input type="checkbox"/> Motorized. <input type="checkbox"/> Swing <input type="checkbox"/> Sliding: <input type="checkbox"/> Cantilevered <input type="checkbox"/> Overhead <input type="checkbox"/> Floor Track.</p>
<p>Site Furnishings – 129300 (02870) <input type="checkbox"/> by Architect <input type="checkbox"/> by Landscape consultant</p>	<p>Benches: <input type="checkbox"/> Concrete <input type="checkbox"/> Wood <input type="checkbox"/> Metal <input type="checkbox"/> Other: _____ Bike racks: <input type="checkbox"/> DV215 Series Varsity Bike Docks by Ground Control Systems <input type="checkbox"/> Dero <input type="checkbox"/> Dumor <input type="checkbox"/> Belson <input type="checkbox"/> Description: _____ Finish: <input type="checkbox"/> Factory powder-coated. Color: <input type="checkbox"/> As selected by Architect. Bollards: <input type="checkbox"/> Metal pipe, Finish: <input type="checkbox"/> Field painted. Color: <input type="checkbox"/> As selected by Architect. <input type="checkbox"/> Concrete filled metal <input type="checkbox"/> Precast Concrete (select model number from Wausau) <input type="checkbox"/> Lighted (by electrical consultant - coordinate)</p>
<p>Site Gratings - 055300 (05530)</p>	<p>Metal gratings: <input type="checkbox"/> Removable Welded Steel Grating: Series GW-2 by McNichols. <input type="checkbox"/> Trench Grates: OT-24 by Urban Accessories.</p>
<p>Flagpoles – 107500 (10350)</p>	<p><input type="checkbox"/> 30 ft mill finished aluminum, Straight shaft, 6 inch diameter with internal halyard by American. Other: _____</p>
<p>Entrance Floor Mats - 124813 (12484) (Normally required for LEED)</p>	<p><input type="checkbox"/> Pedimat by C/S. Outside of building: <input type="checkbox"/> Recessed with frame. <input type="checkbox"/> Surface-applied w/out frame. Inside the building: <input type="checkbox"/> Recessed with frame. <input type="checkbox"/> Surface-applied w/out frame. Carpet type: <input type="checkbox"/> Inside</p>
<p>Foot Grilles - 124816 (12485)</p>	<p>Stainless Steel: Location: <input type="checkbox"/> Outside <input type="checkbox"/> Inside</p>
<p>Traffic Coatings – 071800 (07180)</p>	<p>Material: Polyurethane Coatings. Pedestrian grade: <input type="checkbox"/> Elastatex 500 Urethane Deck by Dex-O-Tex. <input type="checkbox"/> Décor-Flor Broadcast Epoxy Floor by Dex-O-Tex <input type="checkbox"/> Sikalastic 710/715 Traffic System by Sika. Other: _____ Vehicle grade: <input type="checkbox"/> Auto Dex 500 by Dex-O-Tex. Other: _____</p>
<p>Playground <input type="checkbox"/> by Architect <input type="checkbox"/> by Landscape consultant</p>	<p><input type="checkbox"/> Playground surfaces – 321816 (02791). Seamless: <input type="checkbox"/> Spectra Pour CA by SpectraTurf. <input type="checkbox"/> Playground equipment - 116800 (02881). <input type="checkbox"/> Watertable. <input type="checkbox"/> Sandtable. <input type="checkbox"/> Other: _____</p>
<p>Site Enclosures (not on roof) - 055000 metal fabrications</p>	<p><input type="checkbox"/> Trash Enclosures <input type="checkbox"/> Electrical Equipment Enclosures Walls: <input type="checkbox"/> CMU (by structural consultant) <input type="checkbox"/> Chain-link fence <input type="checkbox"/> Steel decorative fence. Gate: <input type="checkbox"/> Chain-link fence <input type="checkbox"/> Steel decorative fence <input type="checkbox"/> Steel corrugated metal <input type="checkbox"/> w/louvered gate.</p>
<p>Detectable Warning - Surfaces 320120</p>	<p>Surface applied system (Raised truncated domes): <input type="checkbox"/> Model A6003648 by Armorcast Products Company. <input type="checkbox"/> Vitrified Polymer Composite (VPC) Cast In Place Detectable/Tactile Warning Surface Tile based on Armor-Tile by Engineered Plastics Inc. <input type="checkbox"/> TekWay Dome-Tiles by StongGo Industries. Other: _____</p>

INTERIOR

<p>Expansion Joint Covers Assemblies – 079500 (05811)</p>	<p><input type="checkbox"/> Exterior roof, 661 Series, curb mounted welded to 651-A09 covering J1100 compression seal (equal in height on both sides) by InPro. <input type="checkbox"/> Non-rated <input type="checkbox"/> Rated <input type="checkbox"/> Exterior, 651-A09 aluminum - surface mount (wall/wall ceiling/ceiling) by InPro. <input type="checkbox"/> Non-rated <input type="checkbox"/> Rated <input type="checkbox"/> Interior, Wall to Wall system: 612 Series - Flush Mount, Polyurethane by InPro. Floor to floor: <input type="checkbox"/> Non-rated <input type="checkbox"/> Rated <input type="checkbox"/> Drip-proof Material: <input type="checkbox"/> Aluminum <input type="checkbox"/> Polyurethane. Floor to wall: <input type="checkbox"/> Non-rated <input type="checkbox"/> Rated <input type="checkbox"/> Material: <input type="checkbox"/> Aluminum <input type="checkbox"/> Polyurethane. Wall to wall: <input type="checkbox"/> Non-rated <input type="checkbox"/> Rated Material: <input type="checkbox"/> Aluminum <input type="checkbox"/> Polyurethane.</p>
<p>Rough Carpentry – 061000 (06100) (Normally by structural consultant)</p>	<p><input type="checkbox"/> Coordinate with structural. <input type="checkbox"/> Plywood Sheathing: See structural drawing for thickness. <input type="checkbox"/> 3/4 inch Fire-retardant plywood on framing. <input type="checkbox"/> Plywood backer boards.</p>
<p>Non-load bearing metal framing – 092216 (09111)</p>	<p><input type="checkbox"/> Steel studs and runners. <input type="checkbox"/> Slip-type head joints. <input type="checkbox"/> Flat strap and backing plate. <input type="checkbox"/> Cold-rolled channel bridging. <input type="checkbox"/> Hat-shaped, rigid furring channel. <input type="checkbox"/> Resilient furring channel. <input type="checkbox"/> Cold-rolled furring channel. <input type="checkbox"/> Z-Shaped furring. <input type="checkbox"/> Wire hangers, brace, and tie. <input type="checkbox"/> Carrying channel.</p>
<p>Miscellaneous Carpentry – 061053 (06105)</p>	<p>Used when Rough Carpentry section is not specified but some interior wood studs are needed. <input type="checkbox"/> Coordinate with structural. <input type="checkbox"/> Plywood backer boards.</p>
<p>Wood base, Wood chair rails, Wood door frames – 064023 (06402)</p>	<p><input type="checkbox"/> Wood base, profile: _____ <input type="checkbox"/> Wood chair rails, profile: _____ <input type="checkbox"/> Wood door frames.</p>
<p>Casework – 064023 (06402) North American Architectural Woodwork Standards, latest edition (NAAWS). – formally Woodwork Institute (WI)</p>	<p>Standards: <input type="checkbox"/> NAAWS (formally WI) (default, CCP shop drawing and certificate.) <input type="checkbox"/> AWI. (for projects outside of Oregon, California, Nevada, and Arizona) Grade: <input type="checkbox"/> Premium <input type="checkbox"/> Custom. Countertops: <input type="checkbox"/> Plastic Laminate (default) <input type="checkbox"/>  Recycled Glass/Concrete. Solid Surfacing: <input type="checkbox"/> Corian by Dupont <input type="checkbox"/> LG <input type="checkbox"/> _____ Quartz Surfacing: <input type="checkbox"/> Caesarstone <input type="checkbox"/> Zodiaq by Dupont <input type="checkbox"/> Silestone by Consentino <input type="checkbox"/> ____ Real Stone: <input type="checkbox"/> Granite Note: See Laboratory Casework section for Epoxy Resin tops. Cabinets: <input type="checkbox"/> Plastic Laminate. <input type="checkbox"/> Wood veneer stained <input type="checkbox"/> Solid Wood Painted. Custom lockers (not manufactured item): <input type="checkbox"/> P-lam <input type="checkbox"/> Wood veneer <input type="checkbox"/> _____ Reception Counters: <input type="checkbox"/> Plastic Laminate (default) <input type="checkbox"/> Wood veneer Solid Surfacing: <input type="checkbox"/> Corian <input type="checkbox"/> Quartz <input type="checkbox"/> Granite Teaching walls: <input type="checkbox"/> Plastic Laminate. <input type="checkbox"/> Wood veneer. Configuration: Door and Drawer Front Style: Flush overlay. <input type="checkbox"/> Swing doors <input type="checkbox"/> Sliding doors <input type="checkbox"/> Drawers <input type="checkbox"/> Swing glass doors <input type="checkbox"/> Sliding glass doors <input type="checkbox"/> Hopper doors. <input type="checkbox"/> Non-magnetic hardware (MRI rooms)</p>
<p>Floor Tile</p>	<p>See Flooring</p>
<p>Sprayed fire proofing – 078100 (07811)</p>	<p>Cementitious sprayed-on fireproofing: <input type="checkbox"/> Grace <input type="checkbox"/> Isolatek Conditions: <input type="checkbox"/> Concealed <input type="checkbox"/> Exposed <input type="checkbox"/> Exposed and field painted. <input type="checkbox"/> Intumescent fire-resistive coating on Exposed (expensive option).</p>

<p>Bulletin Boards – 101200 (10125)</p>	<p>Bulletin boards differ from tackboards; bulletin boards are enclosed in cabinets, and tackboards are not. <u>Claridge</u>: <input type="checkbox"/> Imperial Series <input type="checkbox"/> Contemporary Series <input type="checkbox"/> Rival Series <input type="checkbox"/> Large Contemporary Series <input type="checkbox"/> Revere Series <input type="checkbox"/> Classic Series <input type="checkbox"/> Universal Series <input type="checkbox"/> Deluxe Series</p>
<p>Display Cases – 101200 (10125) (including for trophy)</p>	<p><u>Claridge</u>, aluminum, recessed: <input type="checkbox"/> 370 Series: 3-1/2 inch angel face front. <input type="checkbox"/> 1370 Series: 2 inch radius face front. <input type="checkbox"/> 3370 Series: 3-1/2 inch fluted face front. Display Case Type: <input type="checkbox"/> Recessed <input type="checkbox"/> Surface-Mounted <input type="checkbox"/> Freestanding <input type="checkbox"/> Non-illuminated <input type="checkbox"/> Illuminated. <input type="checkbox"/> Include wood box frame. <input type="checkbox"/> No box frame, box will be site built.</p>
<p>Toilet compartments – 102113 (10155)</p>	<p><input type="checkbox"/> <u>HDPE plastic by Hiny Hinders - Santana/Scranton</u> <input type="checkbox"/> Steel (factory baked enamel). <input type="checkbox"/> Plastic-laminate <input type="checkbox"/> Other: _____ Color: _____ (Santana recently eliminated many colors). Note: Solid Phenolic (Trespa) type is not recommended (custom, need to design all the fittings, not ready made system) Installation: <input type="checkbox"/> Floor mounted - overhead braced. <input type="checkbox"/> Floor to ceiling. <input type="checkbox"/> Ceiling hung.</p>
<p>Directories – 101300 (10410)</p>	<p><input type="checkbox"/> Non-illuminated <input type="checkbox"/> Illuminated.</p>
<p>Lockers</p>	<p>Metal Lockers - 105113 (10505) <input type="checkbox"/> Welded. (expensive, better quality) <input type="checkbox"/> Knock-down. (cheaper, lower quality) Accessories: <input type="checkbox"/> locker benches. <input type="checkbox"/> Locker installed over concrete curb. Wood Lockers - Best to pick a model number from manuf. – 105116 (10506) <input type="checkbox"/> Veneer Wood Lockers <input type="checkbox"/> Plastic Laminate Lockers <input type="checkbox"/> Plastic (HDPE) Lockers</p>
<p>Fire Extinguishers and Cabinets – 104416 (10520)</p>	<p>Fire Extinguishers: <input type="checkbox"/> Multipurpose (2A-10B:C) <input type="checkbox"/> Type K for kitchen. Cabinets by <u>J.L Industries</u>: <input type="checkbox"/> <u>Panorama Series</u>: Frameless Acrylic Door. <input type="checkbox"/> <u>Ambassador Series</u>: Steel Trim and Door. <input type="checkbox"/> <u>Academy Series</u>: Aluminum Trim and Door. <input type="checkbox"/> <u>Cosmopolitan Series</u>: Stainless Steel Trim and Door. <input type="checkbox"/> <u>Embassy Series</u>: Decorative Trimless Recessed Cabinet. <input type="checkbox"/> <u>Cavalier Series</u>: Decorative Bronze or Brass Cabinet. <input type="checkbox"/> <u>Clear VU Series</u>: Acrylic Bubble and Aluminum or Steel Cabinet. <input type="checkbox"/> <u>Corner VU Series</u>: Steel, Stainless Steel and Aluminum Cabinet. <input type="checkbox"/> <u>Classic Series</u>: Economy Galvanized Cabinet. <input type="checkbox"/> <u>Economyline Series</u>: Economy Surface-Mounted Cabinet. <input type="checkbox"/> <u>Decorline Series</u>: Economy Steel or Aluminum Cabinet. Cabinets by particular model numbers: <input type="checkbox"/> #1025W17 aluminum (10-1/2 x 24 x 6” deep) by JL. <input type="checkbox"/> #1015W17 steel. <input type="checkbox"/> #FX1025W17, or #FX1015W17 for fire rated type. <input type="checkbox"/> #1015W12 steel, (10-1/2 x 24 x 6” deep) Ambassador by JL. <input type="checkbox"/> 1600 Series by JL. Cabinets by <u>Larsen’s</u>. <input type="checkbox"/> <u>Gemini Series cabinet by Larsen’s</u>. <input type="checkbox"/> <u>Architectural Series cabinet by Larsen’s</u>. <input type="checkbox"/> <u>Occult by Larsen</u>. <input type="checkbox"/> Steel <input type="checkbox"/> Stainless steel <input type="checkbox"/> Other: _____ Cabinet Door: <input type="checkbox"/> Break Glass <input type="checkbox"/> Acrylic. <input type="checkbox"/> Other: _____ <input type="checkbox"/> Hook only</p>
<p>Payphones - 101700</p>	<p>Telephone enclosure: Stainless steel, Type 304, perforated interior.</p>

(10750)	<input type="checkbox"/> Product: # 1305 by ASI . Other: _____
Library Stack System – 115123 (11054)	Manufacturers: <input type="checkbox"/> Montel <input type="checkbox"/> Spacesaver Operation: <input type="checkbox"/> Manual <input type="checkbox"/> Electrical
Projection Screens – 115213 (11132)	<input type="checkbox"/> Silhouette M (black case) by Draper. <input type="checkbox"/> Series D front projection by Draper. <input type="checkbox"/> Luma 2 : 72" x 96", manual by Draper. <input type="checkbox"/> Luma 2 – Heavy Duty Spring Roller Operated Projection Screen by Draper <input type="checkbox"/> Manually operated ceiling mounted screen; Luma by Draper. <input type="checkbox"/> Targa : 105" x 140", motorized by Draper. <input type="checkbox"/> Artisan Series E: 72" x 96" with Natural maple finish case - ceiling mount. <input type="checkbox"/> Access/Series M, 96 by 96 inches, optional 12 inch extra drop, optional High contrast Grey viewing surface, manual by Draper. <input type="checkbox"/> Tensioned Cosmopolitan Electrol by Da-Lite , wall mounted, Da-Mat screen, 108 x 144 feet, 3 foot black drop, electrically operated. Operation: <input type="checkbox"/> Manual pull-down. <input type="checkbox"/> Electrically operated. Size: <input type="checkbox"/> As indicated. Mounts: <input type="checkbox"/> on hard ceilings <input type="checkbox"/> on suspended ceilings. <input type="checkbox"/> None. <input type="checkbox"/> Lectern w/controls of light, projection screen, shade, projector.
Projector Mount Bracket - 115213 (11132)	<input type="checkbox"/> PRG Precision Gear mount by Peerless. <input type="checkbox"/> Aero 2636 , hard-lid ceilings by Draper. <input type="checkbox"/> CMJ 455 variable position suspended ceiling kit by Peerless. <input type="checkbox"/> LCD LOC II by BMS . Television Mount: <input type="checkbox"/> Bretford TWPW 27R-BK with safety belt and VCR bracket. Others: _____
Assistive Listening Devices – 115217 (11521)	<input type="checkbox"/> Sound Mate #SMP-2 by Telex. <input type="checkbox"/> ASL equipment by Listen Technologies. <input type="checkbox"/> Other: _____
Laboratory Fume Hoods – 115313 (11610)	Fume hoods can't be turned off. Integral part of HVAC system. <input type="checkbox"/> SafeAire II HOPEC IV by Fisher Hamilton <input type="checkbox"/> Supreme Air fume hood by Kewaunee . <input type="checkbox"/> Other: _____
Laboratory Casework – 123553 (12360)	<input type="checkbox"/> Casework: Signature Series , contemporary full overlay, Style 05 by Kewaunee. <input type="checkbox"/> Work surfaces: Epoxy Resin Tops, Kemresin by Kewaunee. <input type="checkbox"/> Other: _____
117610 (11761) View Boxes (X-Ray Illuminators)	<input type="checkbox"/> Surface mounted <input type="checkbox"/> Recessed mounted. <input type="checkbox"/> Series T-S-4-44-120V-DB400-HGP by Vista . <input type="checkbox"/> 4X Hi-Lo by IMRT Phantoms <input type="checkbox"/> Other: _____
Seating	Fixed Audience Seating – 126100 (12610): <input type="checkbox"/> University Seating with PowerUp base and 1000 non-upholster seat by KI. <input type="checkbox"/> Custom Wood back by Irwin . <input type="checkbox"/> Other: _____ Telescoping Stands – 126600 (12660): Manufacturers: <input type="checkbox"/> Hussey <input type="checkbox"/> Interkal <input type="checkbox"/> Irwin <input type="checkbox"/> Others: _____
Emergency Key Box 104116 (10524)	Type: Fireman's: <input type="checkbox"/> Key box – 3200 Series (holds up to 10 keys) "Knox Box" by Knox. <input type="checkbox"/> Switch: Knox Key Switch .
Metal Shelving – 105613 (10671)	<input type="checkbox"/> RiveTier boltless, open metal shelving by Western Pacific Storage. <input type="checkbox"/> Other: _____
105626 (10562) Mobile Storage Shelving	Manufacturer: <input type="checkbox"/> Aurora <input type="checkbox"/> Montel <input type="checkbox"/> Spacesaver Track: <input type="checkbox"/> Recessed <input type="checkbox"/> Surface mounted. If surface mounted, fill between tracks with: <input type="checkbox"/> Plywood sub-floor <input type="checkbox"/> Concrete. End panels: <input type="checkbox"/> Laminate <input type="checkbox"/> Steel. Shelving: <input type="checkbox"/> Cantilevered <input type="checkbox"/> 4-post. <input type="checkbox"/> Steel tops required. How many shelves per unit? <input type="checkbox"/> 4 <input type="checkbox"/> As indicated on Drawings. How deep are the shelves? <input type="checkbox"/> As indicated on Drawings. How high are shelves? <input type="checkbox"/> As indicated on Drawings.

Loading Dock Equipment – 111300 (11160)	<input type="checkbox"/> Hydraulic dock leveler by Kelly . 6 by 7 feet nominal size. <input type="checkbox"/> Laminated dock bumpers. <input type="checkbox"/> Scissors lift by Ecoa . <input type="checkbox"/> Other: _____
Time Clocks 119400 (11940)	<input type="checkbox"/> Series 4000 Terminal by Kronos .
Cubicle Curtains and Tracks – 102123 (10191)	<input type="checkbox"/> Curtains: Use InPro Catalog to pick pattern. Look for “Use for” to determine if the fabric selected is suitable for cubical curtains. <input type="checkbox"/> Tracks: Series 19100 track system Salisbury. <input type="checkbox"/> IV tracks <input type="checkbox"/> Curtain: Salisbury. <input type="checkbox"/> Hangers

INTERIOR CEILINGS

Exposed ceilings	<input type="checkbox"/> As is <input type="checkbox"/> Field Paint <input type="checkbox"/> Epic metal deck (pre-finished surface)
Hard ceilings	<input type="checkbox"/> Gypsum board - 092900 (09250) <input type="checkbox"/> Match existing. <input type="checkbox"/> Manufactured Grid Suspension System for Ceilings (available from Armstrong, USG, etc)
Dropped ceilings	Acoustical Panel Ceilings – 095113 (09511) <input type="checkbox"/> F Fissured, square edge by USG. <input type="checkbox"/> Vinyl Faced Sheetrock Brand Lay-In Ceiling Tile with ClimaPlus performance by USG for Kitchen. Sizes: <input type="checkbox"/> 2 by 2. <input type="checkbox"/> 2 by 4. Hang from Roof Deck of Types: <input type="checkbox"/> Concrete <input type="checkbox"/> Metal Deck <input type="checkbox"/> Concrete filled metal deck MRI rooms ceiling grids: <input type="checkbox"/> Aluminum <input type="checkbox"/> Stainless steel
Acoustical tile over hard ceilings	Acoustical Tile Ceilings – 095123 (09512) <input type="checkbox"/> 1 by 1. <input type="checkbox"/> Match existing. <input type="checkbox"/> Tectum panels screw mounted on gypsum board ceilings. <input type="checkbox"/> Other _____
Decorative ceiling accents	Suspended Decorative Grids – 095436 (09580) <input type="checkbox"/> Metalworks by Armstrong. <input type="checkbox"/> Serpentina by Armstrong. <input type="checkbox"/> Other: _____




INTERIOR WALLS



<p>CMU walls</p>	<p>Masonry - 042000 (04200) (Interior side) Interior: <input type="checkbox"/> As is. <input type="checkbox"/> Painted CMU finish <input type="checkbox"/> Exposed, sandblast. Exterior: <input type="checkbox"/> As is. <input type="checkbox"/> Sealed CMU finish <input type="checkbox"/> Anti-Graffiti CMU finish</p>
<p>Gypsum Walls <input type="checkbox"/> Partitions. <input type="checkbox"/> Ceilings.</p>	<p>Gypsum Board – 092900 (09250) <input type="checkbox"/> Type X, 5/8 inch (Default). <input type="checkbox"/> Type C, 5/8 inch, DensArmorPlus over Certainteed MemBrain vapor barrier with unfaced batt for walls – Mold-prevention. <input type="checkbox"/> Type C, 5/8 inch DensArmorPlus FireCore at ceilings. <input type="checkbox"/> Flexible type – curved application <input type="checkbox"/> Acoustical Gypsum (SoundBreak by National Gypsum). <input type="checkbox"/> Water Resistant (Paint finishes toilet room walls, not for tile backer). <input type="checkbox"/> Abuse-Resistant Gypsum Board (At high traffic area prone to wall damage). <input type="checkbox"/> Cementitious Backer Board (specified in section 093100 Tiles for tile substrate). <input type="checkbox"/> Gypsum Sheathing - Dens-Glass – 061600 (06160) Following Gypsum Finishes are Needed: <input type="checkbox"/> Level 3 <input type="checkbox"/> Level 4 (for flat paint only) <input type="checkbox"/> Level 5 (all other paint gloss) Trim: <input type="checkbox"/> metal <input type="checkbox"/> vinyl Metal reveals: <input type="checkbox"/> Fry Reglet</p>
<p>Shaft-walls</p>	<p>Gypsum shaft-wall assemblies - 092116 (09265) <input type="checkbox"/> Metal CH Stud (able to be installed from one side only) <input type="checkbox"/> Stair-well shaft. <input type="checkbox"/> Elevator shaft <input type="checkbox"/> Plumbing chase (contractor’s option)</p>
<p>Wood paneling</p>	<p>Paneling – 064200 (06420) <input type="checkbox"/> Plastic Laminate. <input type="checkbox"/> Wood veneer. <input type="checkbox"/> Marlite. <input type="checkbox"/> Other: _____</p>
<p>Fiber Reinforced Plastic (FRP) Panels</p>	<p>FRP Panels – 068200 (06820): Used in kitchen/restroom walls rather than using ceramic tiles to save money. <input type="checkbox"/> Marlite (White, default) <input type="checkbox"/> Crane Composites (formerly Kemlite) <input type="checkbox"/> Other: _____</p>
<p>Fiber Reinforced Laminate (FRL) Panels</p>	<p><input type="checkbox"/> Panolam – 068300: Similar to FRP panel above. <input type="checkbox"/> Other: _____</p>
<p>GRG fabrication – 092713 (09271)</p>	<p>Glass-Reinforced Gypsum fabrication: <input type="checkbox"/> GP <input type="checkbox"/> DEC</p>
<p>Medium Density Fiber (MDF) board</p>	<p>Interior Architectural Woodwork – 064023 (06402) <input type="checkbox"/> 5/8 inch MDF wall finish rather than using gypsum board as finish on framing. Use in service corridors for durability.</p>
<p>101100 Visual Display Surfaces - Marker board, chalkboard, tackboard (check with District for pre-approved products)</p>	<p>Visual Surfaces – 101100 (10101): Marker board: <input type="checkbox"/> Series 555 by Polyvision. (indicate size on drawings 4’x8’) <input type="checkbox"/> LCS-II by Claridge (low gloss, double as projection screen). Surface color: white. Other: _____ Chalkboard: <input type="checkbox"/> Series 555 by Polyvision. (indicate size on drawings 4’x8’) Surface color: <input type="checkbox"/> green <input type="checkbox"/> black <input type="checkbox"/> grey <input type="checkbox"/> as selected Other: _____ Tackboard: indicate size on drawings 4’x8’ <input type="checkbox"/> Vinyl covered (default) <input type="checkbox"/> Fabric covered <input type="checkbox"/> unfaced, color cork <input type="checkbox"/> unfaced, natural cork Other: _____ Combo Units: <input type="checkbox"/> Other: _____ Marker Walls: <input type="checkbox"/> Other: _____ Tack Walls (non-acoustical): <input type="checkbox"/> Fabric <input type="checkbox"/> vinyl Other: _____ <input type="checkbox"/> Custom (not manufactured item) Teaching Wall (specified in 06402 Interior Architectural Woodwork) Include: <input type="checkbox"/> Markerboard <input type="checkbox"/> Chalkboard <input type="checkbox"/> Tackboard Frame: Clear anodized aluminum (default)</p>

<p>101117 Electronic Markerboards – interactive white board</p>	<p><input type="checkbox"/> Simplicity Touch IFP by Recordex. <input type="checkbox"/> Other: _____</p>
<p>Display Cases – 101200 (10125)</p>	<p>Trophy Cases: Claridge. <input type="checkbox"/> Model 3370 with fluted face front. <input type="checkbox"/> Model 3370</p>
<p>Wall Coverings – 097200(09720)</p>	<p>Vinyl coated fabric: <input type="checkbox"/> Type II wall covering for tackboard with Teflon by Koroseal.</p>
<p>Tackable wall surface (Site Fabricated)</p>	<p>Fabric-Wrapped Panels – 097723 (09771) Basis of Design Product: _____ <input type="checkbox"/> Tackable board or wall – 101100 (10101) fabricated at factory, not site fabricated. <input type="checkbox"/> Site fabricated tackable panels, Fabricmate. <input type="checkbox"/> Site fabricated acoustical panels Thickness: <input type="checkbox"/> 1/2 inch: Tackable (0.45 NRC) <input type="checkbox"/> 1 inch: Acoustical. (0.80 NRC) Fabric: Replaceable fabric. Fabric is not integral with board (easier to replace and repair). <input type="checkbox"/> Guilford of Maine, FR701, Style 2100. <input type="checkbox"/> Maharam Stretched-Fabric Wall Systems 09773 <input type="checkbox"/> Site fabricated, Fabricmate. <input type="checkbox"/> Other: _____</p>
<p>Acoustical wall surface</p>	<p>Acoustical Wall Panels - 098433 (09841) <input type="checkbox"/> Essi Acoustical. <input type="checkbox"/> Soundsoak by Armstrong. <input type="checkbox"/> M-90 by Empire Acoustical Systems. <input type="checkbox"/> QuietPerf by Noise Barriers. <input type="checkbox"/> Sono-Con SC-6P by Phoenix-E. (equal to QuietPerf) <input type="checkbox"/> Other: _____</p>
<p>Wall guards</p>	<p>Wall Guards – 102600 (10265) Corner guards: <input type="checkbox"/> PVC <input type="checkbox"/> Stainless steel <input type="checkbox"/> Other: _____ Chair Rail: <input type="checkbox"/> Korowood Chair rails model BW90 by Korogard. <input type="checkbox"/> CR-3 Chair rail (maple stain to be selected) by InPro Sheet wall protection: <input type="checkbox"/> Rigid sheet vinyl by In Pro Corp. <input type="checkbox"/> Other: _____</p>
<p>Room Signs - 101400 (10431)</p>	<p>Panel signs (room signs including ADA toilet signs) <input type="checkbox"/> Best Signs <input type="checkbox"/> Other: _____</p>
<p>102219 Demountable Partitions</p>	<p>Manufacturers: <input type="checkbox"/> Dirtt <input type="checkbox"/> Genius by KI <input type="checkbox"/> SteelCase <input type="checkbox"/> Modular Walls by Herman Miller. <input type="checkbox"/> Other: _____</p>

INTERIOR FLOORING

<p>Self Leveling Underlayment - 035400</p>	<p>Cement Based: <input type="checkbox"/> Dek C-Ment by Maxxon. Hydraulic Cement Based: <input type="checkbox"/> K15 by Ardex. Gypsum Based: <input type="checkbox"/> Commercial Topping by Maxxon. <input type="checkbox"/> LEVELROCK 3500 by USG. <input type="checkbox"/> Flo-Top by Euclid Chemical Company Acoustical Mat: <input type="checkbox"/> Acousti-Mat by Maxxon. <input type="checkbox"/> Levelrock Brand Sound Reduction Mat by USG</p>
<p>Concrete Floor Sealer - 071910 (07190)</p>	<p>Cheap way to seal concrete floors in back of office to prevent dusting (mech room, electrical room, etc.) <input type="checkbox"/> Clear Sealer only: Cementone Clear Sealer by Scofield. Exposed to view where staining is required. <input type="checkbox"/> Concrete stain and sealer: Lithochrome Chemstain Classic Stain by Scofield.</p>
<p>Polished Concrete Finishing - 033517</p>	<p>Manufacturers: <input type="checkbox"/> Consolideck Cleaner/Degreaser by Prosoco. <input type="checkbox"/> PermaShine by LM. <input type="checkbox"/> RetroPlate 99 by Advanced Floor Products. <input type="checkbox"/> PC-T by Ardex <input type="checkbox"/> FormulaOne by Scofield. Level of Shine: <input type="checkbox"/> Level 1 - Low Gloss: Honed/matte finish, polished up to and including 400 grit resin diamonds, a gloss reading of 10-20. <input type="checkbox"/> Level 2 - Medium Gloss: Moderate gloss finish, polished up to and including 800 grit resin diamonds, a gloss reading of 20-30. <input type="checkbox"/> Level 3 (default): High Gloss: High gloss/Mirror finish, polished up to and including 1,600/1,800 grit resin diamonds, gloss reading of 30-50. <input type="checkbox"/> Level 4 (too shiny, maintenance issue): Very High Gloss: Polished up to and including a 3,000 grit resin diamonds, gloss reading 60+. <input type="checkbox"/> Integral Color: _____ <input type="checkbox"/> none. <input type="checkbox"/> Stained Color: _____ <input type="checkbox"/> none.</p>
<p>Resilient Floor Tile - 096519 (09651) (need to distinguish from “tile” vs “sheet” as they are specified in different sections)</p>	<p>Solid Vinyl Tile <input type="checkbox"/> Lightwood, 6” planks by Toli. <input type="checkbox"/> SafeTcork by Roppe. <input type="checkbox"/> Other: _____ Luxury Vinyl Tile (LVT). <input type="checkbox"/> Natural Creations - EarthCuts by Armstrong. <input type="checkbox"/> Natural Creations - ArborArt by Armstrong. <input type="checkbox"/> Contour Series Luxury Vinyl Tile by Tandus/Centiva. <input type="checkbox"/> Uncommon Ground 4 by Shaw Hard Surface <input type="checkbox"/> Main Street Residential LVP by Urban Surfaces <input type="checkbox"/> Select LVT, Amtico Collection by Mannington <input type="checkbox"/> Town & Country Series by Hallmark Flooring <input type="checkbox"/> Other: _____ Composition Tile <input type="checkbox"/> Marmoleum Composition Tile (MCP) by Forbo Rubber Floor Tile <input type="checkbox"/> ECOstone flooring by ECOSurfaces <input type="checkbox"/> ECOrocks flooring by ECOSurfaces <input type="checkbox"/> Metallurgy Resilient Rubber Tile Flooring by Johnsonite <input type="checkbox"/> Minerality Rubber Floor Tiles by Johnsonite <input type="checkbox"/> Other: _____ Vinyl Composition Tile (VCT) <input type="checkbox"/> Excelon - Imperial Texture by Armstrong. <input type="checkbox"/> Excelon - StoneTex by Armstrong.</p>

	<input type="checkbox"/> Excelon Flooring, Raffia by Armstrong <input type="checkbox"/> Excelon Flooring, ChromaSpin by Armstrong <input type="checkbox"/> Essentials by Mannington <input type="checkbox"/> Touchstone by Mannington <input type="checkbox"/> Quartz tile by Altro. <input type="checkbox"/> Other: _____ Recycled Vinyl Tile <input type="checkbox"/> Eco surfaces  <input type="checkbox"/> Other: _____
Vinyl sheet - 096516 (09652)	<input type="checkbox"/> Classic Corlon by Armstrong with integral base. <input type="checkbox"/> Connection Corlon by Armstrong : <input type="checkbox"/> Medintech by Armstrong . <input type="checkbox"/> Mature by TOLI . <input type="checkbox"/> Other: _____ Wall Base: <input type="checkbox"/> integral base <input type="checkbox"/> Resilient base <input type="checkbox"/> Wood base
Linoleum -096517 (09654) 	<input type="checkbox"/> Marmorette by Armstrong . <input type="checkbox"/> Granette with NATURCote by Armstrong <input type="checkbox"/> Marmoleum Dual Tile by Forbo . <input type="checkbox"/> Marmoleum Real by Forbo <input type="checkbox"/> Marmoleum Dual [Tile] [Sheet] by Forbo <input type="checkbox"/> Marmoleum Composition Tile (MCT) Linoleum Floor by Forbo <input type="checkbox"/> Harmonium xf by Johnsonite. <input type="checkbox"/> Veneto Collection by Tarkett. <input type="checkbox"/> Other: _____ Wall Base: <input type="checkbox"/> integral base <input type="checkbox"/> Resilient base <input type="checkbox"/> Wood base
Static dissipative - 096536 (09661)	<input type="checkbox"/> Rubber Tile: Mega al, Article 200, smooth surface, 24 x 24 by Noraplan . <input type="checkbox"/> Rubber Sheet: Noraplan mega al, Article 100, roll size by Noraplan. <input type="checkbox"/> Rubber Tile for Access Floor Panels: Mega al, Article 296, smooth surface, 24 x 24 by Noraplan. <input type="checkbox"/> Other: _____
Resinous (Epoxy) Flooring - 096723 (09672)	Stonhard Products <input type="checkbox"/> Stonshield HRI [restrooms]. <input type="checkbox"/> Stonshield GSI [Higher end restrooms cost 20% more installed than HRI]. <input type="checkbox"/> Stonclad GS [warming kitchens]. <input type="checkbox"/> Stonclad UT [full service kitchens]. Dex-O-Tex <input type="checkbox"/> Cheminert K with Quick-glaze top coat. <input type="checkbox"/> Décor-flor. <input type="checkbox"/> Terracolor. <input type="checkbox"/> Other: _____
Carpet 	Carpet (sheet) - 096816 (09680): <input type="checkbox"/> LMUSD: Lucia Mar with UltraLoc MP backing by Shaw . <input type="checkbox"/> No Rules Collection by Shaw . <input type="checkbox"/> Double Knit by Shaw . <input type="checkbox"/> http://www.tandus.com/product-catalog/flooring/plateau_51081.html . <input type="checkbox"/> Travertine 40009 by Tandus . <input type="checkbox"/> Charlemont by Bentley Prince Street <input type="checkbox"/> UPC by Bentley Prince Street <input type="checkbox"/> CYP 42 by Durkan <input type="checkbox"/> Kami by Mannington . <input type="checkbox"/> Surreal MC007 by Mohawk . <input type="checkbox"/> Faculty IV by Lees . Bello III by LEES. <input type="checkbox"/> Other: _____ Carpet Tile - 096813 (09681): <input type="checkbox"/> Entropy by Interface . <input type="checkbox"/> Braided by Interface . <input type="checkbox"/> Silurian GlasBac Tile by Interface .

	<input type="checkbox"/> FLOR by Interface. <input type="checkbox"/> Super Flor by Interface. <input type="checkbox"/> Surreal MC007 by Mohawk. <input type="checkbox"/> Stimulus, P/6565 blip by Milliken. <input type="checkbox"/> Savanna by Milliken. <input type="checkbox"/> Radiance by Shaw. <input type="checkbox"/> Disperse Tile by Shaw. <input type="checkbox"/> No Rules Collection by Shaw. <input type="checkbox"/> Diffuse by Shaw. <input type="checkbox"/> Fade Tile by Shaw. <input type="checkbox"/> Brainstorm #03387, ER3 Modular by Tandus. <input type="checkbox"/> Landscape Colours by Tandus. <input type="checkbox"/> Abrasive Action by Tandus (interior walk-off mat) <input type="checkbox"/> Other: _____
Wall Base	Rubber Base - 096513 (09651): <input type="checkbox"/> Type TS by Burke. (TS more expensive than TP type) <input type="checkbox"/> Type TP by Johnsonite. Style: _____ <input type="checkbox"/> Resilient flooring: Cove (with top-set toe) <input type="checkbox"/> Carpet: Straight (toeless). Base Height: As indicated. <input type="checkbox"/> Wood base – 064023 (06402)
Wood Flooring - 096400 (09640):	Basis of Design Product: _____ Material: <input type="checkbox"/> Solid wood. Engineered (laminates): <input type="checkbox"/> Armstrong <input type="checkbox"/> Pergo <input type="checkbox"/>  Bamboo: <input type="checkbox"/> Calibamboo. <input type="checkbox"/> Re-claimed wood planks. Width: <input type="checkbox"/> Strip, 1-1/2 to 2-1/4 inches wide, random lengths. <input type="checkbox"/> Plank, 3 to 8 inches wide, random lengths. <input type="checkbox"/> Parquet. Species: _____ Wood Finish: <input type="checkbox"/> Field Finished: Solid (traditional) <input type="checkbox"/> Factory Finished. Attachment Method: <input type="checkbox"/> Glue <input type="checkbox"/> Nailed Substrate: <input type="checkbox"/> Wood <input type="checkbox"/> Concrete Wall base: <input type="checkbox"/> Matching Wood <input type="checkbox"/> Rubber base
Concrete moisture barrier	Concrete Moisture Barrier - 071920 (07191) Applied when moisture test fails. Need to bead blast floor prior to application.
Concrete moisture test	Concrete Moisture Test - 014150 (01415) Test Prior to installing carpet, resilient floor over concrete.
Access flooring  - 096900 (10270)	Equipment Room: <input type="checkbox"/> Panel: RWC100 (1000 lbf concentrated load) concrete filled, cornerbolt steel panel. Understructure: M285 pedestal, B800 base, BG-4 steel stringer, 4x4' rigid grid system stringer system by Maxcess. MRI Room: <input type="checkbox"/> Panel: H-24/60 (1750 lbf concentrated load), solid aluminum. Other: _____ Pedestal Height: As indicated. (12 inches-default, confirm floor is depressed) Laminated Floor Tile for access flooring: <input type="checkbox"/> Nevamar Company, LLC, with Maxcess SpecTrim edges. Floor coverings: <input type="checkbox"/> VCT <input type="checkbox"/> Solid vinyl tile <input type="checkbox"/> Static-control <input type="checkbox"/> raw (none). Type: <input type="checkbox"/> Steel (cheaper) <input type="checkbox"/> Aluminum (more expensive, MRI rooms)

TILE – 093000 (09310)

Ask for [TCNA's TCA manual](#) if you don't have one.

Tile Manufacturers	<input type="checkbox"/> Daltile/American Olean <input type="checkbox"/> Crossville <input type="checkbox"/> Interceramic
Grout/Mortar Manufacturers	<input type="checkbox"/> Custom <input type="checkbox"/> Mapei <input type="checkbox"/> Laticrete
Floor Thickset (coordinate 2" slab depression with structural) Location: <input type="checkbox"/> On grade <input type="checkbox"/> Upper floors. (Callout installation methods by TCNA numbers.)	Basis of Design style, color, manuf: _____ Type: <input type="checkbox"/> Unglazed Ceramic Mosaic Tile <input type="checkbox"/> Other: Size: <input type="checkbox"/> 2x2 inches <input type="checkbox"/> As indicated on Drawings. Substrate: <input type="checkbox"/> Concrete flooring <input type="checkbox"/> Plywood flooring Concern with floor deflection? <input type="checkbox"/> Yes <input type="checkbox"/> No. Thickset (2 inch depression required): <input type="checkbox"/> TCNA #F121 (w/waterproofing) <input type="checkbox"/> TCNA #F132 (no waterproofing) Thinset: <input type="checkbox"/> TCNA #F122 (w/waterproofing) <input type="checkbox"/> TCNA #F113 (no waterproofing) Shower: <input type="checkbox"/> TCNA #B415 (waterproof membrane, with TCNA W244 wall). Use thinset method for remodeling tiled floors, unless new floor drain (by plumbing consultant) is also needed.
Base	Basis of Design type, color, manuf: _____
Walls	Basis of Design style, color, manuf: _____ Type: <input type="checkbox"/> Field Glazed Ceramic Tile <input type="checkbox"/> Accent Glazed Ceramic Tile <input type="checkbox"/> Other: Size: <input type="checkbox"/> 4x4 inches <input type="checkbox"/> As indicated on Drawings. Thinset: <input type="checkbox"/> TCNA #W244 (with or without water barrier) <input type="checkbox"/> Tile over cement board. <input type="checkbox"/> Gypsum board and painted above wainscot tiles.
Threshold at Tile transition	Stone thresholds: <input type="checkbox"/> Marble <input type="checkbox"/> Granite <input type="checkbox"/> Solid polymer thresholds.
Ceiling	<input type="checkbox"/> TCNA #SR614 (installation over fiber-reinforced gypsum board over waterproof membrane).

WINDOWS

Sound rated	General: If needed indicate STC values where required for each windows types.
Steel Windows- Hollow Metal (Cold formed) - 085123 (08510) <input type="checkbox"/> Exterior <input type="checkbox"/> Interior	Coordinate this item with 08110 Steel door and frames.
	Fire-rated: <input type="checkbox"/> 20 min. <input type="checkbox"/> 40 min <input type="checkbox"/> 60 min <input type="checkbox"/> Non-fire-rated.
	Basis of design: <input type="checkbox"/> DV Fyre-Tec. <input type="checkbox"/> Optimum. <input type="checkbox"/> HM door manufacturers
	<input type="checkbox"/> Fixed. <input type="checkbox"/> Sliding <input type="checkbox"/> Casement <input type="checkbox"/> Awning <input type="checkbox"/> Other:
	Glazing Type: Cross-reference – 088000 (08800) for actual glazing type. <input type="checkbox"/> clear insulated. <input type="checkbox"/> clear insulated w/ low-e <input type="checkbox"/> single pane <input type="checkbox"/> other: _____
	Finish: <input type="checkbox"/> Standard field paint - 099100 (09910) <input type="checkbox"/> Factory finished. <input type="checkbox"/> High Performance field paint – 099600 (09960)
Steel Windows - Solid Steel (Hot rolled) - 085123 (08510) – every expensive. <input type="checkbox"/> Exterior <input type="checkbox"/> Interior	Fire-rated: <input type="checkbox"/> 20 min. <input type="checkbox"/> 40 min <input type="checkbox"/> 60 min <input type="checkbox"/> Non-fire rated.
	Basis of Design: <input type="checkbox"/> Jamestown 175, 1-3/4" deep by Hope's Windows, Inc. <input type="checkbox"/> Torrance Steel Window <input type="checkbox"/> Other: _____
	<input type="checkbox"/> Fixed. <input type="checkbox"/> Sliding <input type="checkbox"/> Casement <input type="checkbox"/> Awning <input type="checkbox"/> Single Hung <input type="checkbox"/> Double Hung <input type="checkbox"/> Projected <input type="checkbox"/> Other: _____
	Glazing Type: Cross-reference – 088000 (08800) for actual glazing data. <input type="checkbox"/> clear insulated. <input type="checkbox"/> clear insulated w/ low-e <input type="checkbox"/> single <input type="checkbox"/> other: _____
	<input type="checkbox"/> Standard field painted – 099100 (09910) <input type="checkbox"/> Factory painted. <input type="checkbox"/> High Performance Coatings field painted – 099600 (09960)
	<input type="checkbox"/> Fixed. <input type="checkbox"/> Sliding <input type="checkbox"/> Casement <input type="checkbox"/> Awning <input type="checkbox"/> Single Hung <input type="checkbox"/> Double Hung <input type="checkbox"/> Projected <input type="checkbox"/> Other: _____
Aluminum Windows - 085113 (08520) <input type="checkbox"/> Exterior <input type="checkbox"/> Interior	Glazing Type: Cross-reference 08800 for actual glazing data. <input type="checkbox"/> Clear insulated. <input type="checkbox"/> clear insulated w/ low-e <input type="checkbox"/> single <input type="checkbox"/> other: _____
	<input type="checkbox"/> Clear anodized <input type="checkbox"/> Color anodized: _____
	<input type="checkbox"/> 2-coat Kynar 70% <input type="checkbox"/> 2-coat Kynar 70% Mica <input type="checkbox"/> 3-coat Kynar 70% Color: _____
	Better to cross-reference other section to match if possible.
Wood Windows – 085200 (08550) <input type="checkbox"/> Exterior <input type="checkbox"/> Interior	Category: <input type="checkbox"/> Stock windows. <input type="checkbox"/> Custom windows as detailed on Drawings [to match existing].
	Types: <input type="checkbox"/> Fixed. <input type="checkbox"/> Sliding <input type="checkbox"/> Casement <input type="checkbox"/> Awning <input type="checkbox"/> Single Hung <input type="checkbox"/> Double Hung <input type="checkbox"/> Projected <input type="checkbox"/> Other: _____
	Muntin bars: <input type="checkbox"/> True divided lites <input type="checkbox"/> Simulated divided lites
	Glazing: <input type="checkbox"/> clear insulated <input type="checkbox"/> clear insulated w/low -e <input type="checkbox"/> single pane.
Clearstory Windows	Glazing: <input type="checkbox"/> Glass <input type="checkbox"/> Kalwall .
	Type: <input type="checkbox"/> Fixed <input type="checkbox"/> None. Operable: <input type="checkbox"/> Manual <input type="checkbox"/> Electrical <input type="checkbox"/> None.
	Same window as: _____
Window Wall	Glazing: <input type="checkbox"/> Glass <input type="checkbox"/> Kalwall .
Aluminum Frames - 081216	Consider using this section for “interior” applications of entrances and storefront. Much cheaper compare to exterior types and unnecessary.
	Storefronts: Wilson Partitions . (Part of Arcadia Windows) <input type="checkbox"/> Series 525 with 2 inch trim.
	Western Integrated Materials, Inc. <input type="checkbox"/> Series 487 with 2 inch trim. <input type="checkbox"/> Series 725 with 2 inch trim.
	<input type="checkbox"/> Modulex, Inc : Division of Pacific National Group.
	<input type="checkbox"/> RACO Interior Products, Inc.
	<input type="checkbox"/> Other: _____
	Doors: <input type="checkbox"/> Wide stile <input type="checkbox"/> Medium stile <input type="checkbox"/> Narrow stile
	Finish: <input type="checkbox"/> Clear anodized <input type="checkbox"/> Color anodized: _____
	<input type="checkbox"/> 2-coat Kynar 70% <input type="checkbox"/> 2-coat Kynar 70% Mica <input type="checkbox"/> 3-coat Kynar 70% Color: _____
	Better to cross-reference other section to match if possible.
	Glazing:

<p>Storefront - 084113 (08411)</p> <p><input type="checkbox"/> Exterior <input type="checkbox"/> Interior</p> <p>Glazing: Storefront: <input type="checkbox"/> Clear insulated <input type="checkbox"/> Clear insulated & e-coat</p> <p>Door: <input type="checkbox"/> Clear 1/4 inch single. <input type="checkbox"/> Insulated glazing on doors (rare).</p>	<p><input type="checkbox"/> Tempered, single pane. <input type="checkbox"/> Clear insulated <input type="checkbox"/> clear insulated w/low -e</p> <p>Storefront (Window): <input type="checkbox"/> Trifab Versaglaze 451, Non-thermal, 2" x 4-1/2" by Kawneer. <input type="checkbox"/> AFG451 Series, 2" x 4-1/2" by Arcadia. <input type="checkbox"/> TC470 Series, 2-1/4 by 4-1/2 inch by Arcadia. <input type="checkbox"/> 451-S, 2 by 4-3/4 inch by US Aluminum. Other: _____</p> <p>Swing Door: <input type="checkbox"/> Wide (5 inch), Tuffline 500 by Kawneer. <input type="checkbox"/> Medium (3-1/2 inch) Tuffline 350 by Kawneer. <input type="checkbox"/> Narrow (2-1/8 inch) 190 by Kawneer. <input type="checkbox"/> WS512 Series, Wide Stile Door 1-3/4" by Arcadia. <input type="checkbox"/> Model 850, 5 inch wide stiles, heavy-duty doors by US Aluminum <input type="checkbox"/> Model 800, 3-1/2 inch medium stile, heavy-duty doors by US Aluminum <input type="checkbox"/> Other: _____</p> <p>Note: Tuffline is 3 times more expensive than regular line but so much better. Door wall thickness: <input type="checkbox"/> Heavy (Tuffline, 0.188 inch) <input type="checkbox"/> Standard (0.125 inch) Wall Frame: <input type="checkbox"/> Heavy <input type="checkbox"/> Standard <input type="checkbox"/> Swing, tempered, full glazing (1/4 inch clear single glazing) Finish: <input type="checkbox"/> Clear anodized <input type="checkbox"/> Kynar 70 %: Color: _____ Transom: <input type="checkbox"/> Single <input type="checkbox"/> Insulated <input type="checkbox"/> Tinted <input type="checkbox"/> None Sidelight: <input type="checkbox"/> Single <input type="checkbox"/> Insulated <input type="checkbox"/> Tinted <input type="checkbox"/> None Finish: <input type="checkbox"/> Clear anodized <input type="checkbox"/> Color anodized: _____ <input type="checkbox"/> 2-coat Kynar 70% <input type="checkbox"/> 2-coat Kynar 70% Mica <input type="checkbox"/> 3-coat Kynar 70%</p> <p><input type="checkbox"/> Sliding Aluminum Framed Glass Door – 083213 (08163)</p>
<p>Glazed Aluminum Curtain Walls – 084413 (08911)</p>	<p>Arcadia: <input type="checkbox"/> OPG-1500 Thermal, 2 1/4" X 5-1/2" for 1/4" – 1-1/8" Glass. <input type="checkbox"/> OPG-1900 Thermal, 2-1/4" x 7". <input type="checkbox"/> OPG-1800, 2-1/4" x 7". <input type="checkbox"/> OPG-3000 Thermal, 2 1/4" X 10" for 1/4" – 1-1/8" Glass. <input type="checkbox"/> OPG-3010 Thermal, 3" X 10" for 1/4" – 1-1/8" Glass. <input type="checkbox"/> OPG-6000, 2-1/4" x 6". 2 and 4 sided structural glazing.</p> <p>Kawneer: <input type="checkbox"/> 1600 Wall System 1 <input type="checkbox"/> Series 1600 Wall System 2 <input type="checkbox"/> 1600UT (Ultra Thermal) System 1 <input type="checkbox"/> 1620 SSG <input type="checkbox"/> Clearwall – Screw Spline <input type="checkbox"/> Clearwall – Shear Block <input type="checkbox"/> System 5600, 2-1/4 inch system by EFCO. <input type="checkbox"/> Other: _____ <input type="checkbox"/> Matching aluminum sunshades: <input type="checkbox"/> Outrigger type <input type="checkbox"/> Other: _____</p> <p>Finish: <input type="checkbox"/> Clear anodized <input type="checkbox"/> Color anodized: _____ <input type="checkbox"/> 2-coat Kynar 70% <input type="checkbox"/> 2-coat Kynar 70% Mica <input type="checkbox"/> 3-coat Kynar 70%</p>
<p>WindowWall (can be combined into Curtainwall or Storefront section)</p>	<p>Arcadia: <input type="checkbox"/> AG601 (center glazed) and AFG601 (offset glazed) Series: 2"x6". <input type="checkbox"/> AFG7251 Series: 2-1/2"x7-1/4". <input type="checkbox"/> TC 770 Series: 2-1/2"x7".</p> <p>Finish: <input type="checkbox"/> Clear anodized <input type="checkbox"/> Color anodized: _____ <input type="checkbox"/> 2-coat Kynar 70% <input type="checkbox"/> 2-coat Kynar 70% Mica <input type="checkbox"/> 3-coat Kynar 70%</p>
<p>Glazing – 088000 (08800)</p>	<p>Need values from Mechanical Consultant. Windows: Insulated, 1 inch total (2 pane of 1/4 and 1/2 of air space) Clear glazing: <input type="checkbox"/> Insulated glazing by Oldcastle.</p>

	<p><input type="checkbox"/> Other: _____</p> <p>Clear, low-e glazing:</p> <p><input type="checkbox"/> Solarban 60 (low -e coating) by PPG.</p> <p><input type="checkbox"/> Solarban 67 (low -e coating) by PPG.</p> <p><input type="checkbox"/> Solarban 70XL (low -e coating) by PPG.</p> <p><input type="checkbox"/> Other: _____</p> <p>Tinted, low-e glazing:</p> <p><input type="checkbox"/> Solarban 60 (low -e coating) by PPG.</p> <p><input type="checkbox"/> Solarban 67 (low -e coating) by PPG.</p> <p><input type="checkbox"/> Solarban 70XL (low -e coating) by PPG.</p> <p><input type="checkbox"/> Other: _____</p> <p><input type="checkbox"/> Tint Color: _____</p>
<p>Flexible Sheet Flashing - 076500 (07650)</p>	<p>Use at all openings to minimize water intrusions.</p> <p><input type="checkbox"/> Vycor Plus by WR Grace.</p> <p><input type="checkbox"/> Tyvek flashing system, commercial by DuPont.</p> <p><input type="checkbox"/> Other: _____</p>
<p>Horizontal louver blinds - 122113 (12491)</p>	<p><input type="checkbox"/> Riviera, 1 inch wide aluminum by Levolor.</p> <p><input type="checkbox"/> Riviera, 2 inch wide aluminum by Levolor.</p> <p><input type="checkbox"/> CD60, 1 inch wide aluminum by Hunter Douglas.</p> <p><input type="checkbox"/> Chalet Woods, 2 inch wide Basswood by Hunter Douglas.</p> <p><input type="checkbox"/> EverWood, 2 inch wide composite wood by Hunter Douglas.</p> <p><input type="checkbox"/> Other: _____</p>
<p>Vertical louver blinds - 122116 (12492)</p>	<p>Basis of Design: _____</p>
<p>Roller Window Shades - 122413 (12494)</p>	<p><input type="checkbox"/> 0706 Oyster Blackout by MechoShade.</p> <p><input type="checkbox"/> Thermo Veil Basketweave Collection, 1300 Series by MechoShade.</p> <p><input type="checkbox"/> Vimco by Lutron.</p> <p><input type="checkbox"/> Electrically Operated Roller Shades Sivoia QED by Lutron.</p> <p>Operation: <input type="checkbox"/> Manual pull-chain <input type="checkbox"/> Electrically operated.</p> <p>Configuration:</p> <p><input type="checkbox"/> Solar: ThermoVeil 1300 Series basket weave by MechoShade.</p> <p><input type="checkbox"/> Blackout: ThermoVeil 700 Series for A/V by MechoShade.</p> <p><input type="checkbox"/> Dual shade (both solar and blackout)</p> <p><input type="checkbox"/> Other: _____</p> <p>Single shades bracket: <input type="checkbox"/> SlimLine <input type="checkbox"/> Standard <input type="checkbox"/> Pocket Extended <input type="checkbox"/> Extended.</p> <p><input type="checkbox"/> Double shades #10, blackout rear, sunscreen front.</p> <p><input type="checkbox"/> Double shades #15, blackout top, sunscreen bottom.</p> <p>Mounting: <input type="checkbox"/> Surface mounted <input type="checkbox"/> Surface mounted with fascia</p> <p><input type="checkbox"/> Recess mounted with ceiling pocket and fascia</p> <p><input type="checkbox"/> Recess mounted without ceiling pocket or fascia.</p>

DOORS

(Need to see the Door Schedule sheet)

Sound rated	General: If needed indicate STC values where required for each door types.
Steel Doors and Frames - 081113 (08110) Interior: <input type="checkbox"/> 18 gage doors w/ 16 gage welded frames. (knock-down for LMUSD) Exterior: <input type="checkbox"/> 16 gage doors w/ 16 gage welded frames. (14 gage frame for LMUSD)	Manufacturers: <input type="checkbox"/> Steelcraft <input type="checkbox"/> Ceco <input type="checkbox"/> Curries <input type="checkbox"/> Timely (factory-finished frames) <input type="checkbox"/> Other: _____
	Fire-rated: <input type="checkbox"/> 20 min. <input type="checkbox"/> 45 min <input type="checkbox"/> 60 min <input type="checkbox"/> 1-1/2 hr <input type="checkbox"/> Non fire rated Glazing (1/4" default) at: <input type="checkbox"/> Narrow lite. <input type="checkbox"/> Half. <input type="checkbox"/> Full <input type="checkbox"/> None <input type="checkbox"/> Safety glazing for fire-rated. (Wire glass is not allowed.) <input type="checkbox"/> 1-way security mirror glazing.
	Louver: <input type="checkbox"/> at bottom. <input type="checkbox"/> Full panel <input type="checkbox"/> Size as indicated <input type="checkbox"/> Fusible link for fire-rated. <input type="checkbox"/> Transom louvers (10200)
	Transom Glazing Type: <input type="checkbox"/> Insulated <input type="checkbox"/> Single <input type="checkbox"/> None Sidelight Glazing Type: <input type="checkbox"/> Insulated <input type="checkbox"/> Single <input type="checkbox"/> None
	<input type="checkbox"/> Factory primed for field painted - 099100 (09910) -default. <input type="checkbox"/> Factory primed for field high performance coatings - 099600 (09960) <input type="checkbox"/> Factory finished w/ powdered or enamel.
	See Storefront in Windows.
Aluminum Entrance Doors - 084113 (08411)	See Storefront in Windows.
Automatic Entrance Doors - 084229 (08460) <input type="checkbox"/> Exterior. <input type="checkbox"/> Interior.	Following furnish aluminum doors, operators, and sensors as one system. Manufacturers: <input type="checkbox"/> Horton <input type="checkbox"/> Door-O-Matic <input type="checkbox"/> Stanley <input type="checkbox"/> Other: _____ Door type: <input type="checkbox"/> Sliding <input type="checkbox"/> Swing (Need guard rail) Finish: <input type="checkbox"/> Clear anodized <input type="checkbox"/> Other: _____ <input type="checkbox"/> Match storefront or windows system finish. (difficult to Kynar)
All-Glass Entrance and Storefronts- 084126 (08450)	Manufacturers: <input type="checkbox"/> CRL <input type="checkbox"/> Dormakaba <input type="checkbox"/> Klein <input type="checkbox"/> Other: _____ Stainless Steel Fitting: <input type="checkbox"/> Patch fittings <input type="checkbox"/> Continuous rail fittings <input type="checkbox"/> Exit Devices
Flush Wood Doors – 081416 (08211) [Need to distinguish flush vs stile and rail when both are in project] <input type="checkbox"/> Exterior (no warranty) <input type="checkbox"/> Interior (lifetime-warranty) Special: <input type="checkbox"/> Pocket Doors <input type="checkbox"/> Sliding Doors	Manufacturers: <input type="checkbox"/> Masonite (Marshfield-Algoma) <input type="checkbox"/> Eggers Industries (VT industries) <input type="checkbox"/> Haley Brothers <input type="checkbox"/> Other: _____
	Fire-rated: <input type="checkbox"/> 20 min. <input type="checkbox"/> 40 min <input type="checkbox"/> 60 min <input type="checkbox"/> Non fire rated
	Face material: <input type="checkbox"/> Plastic Laminate <input type="checkbox"/> High-Impact <input type="checkbox"/> Medium Density Overlay (MDO) -field painted. <input type="checkbox"/> Veneers: <input type="checkbox"/> plain sliced white maple <input type="checkbox"/> plain sliced white birch <input type="checkbox"/> Other: _____
	Solid Core (default): <input type="checkbox"/> Structural composite lumber (SCL – default. Better than SLC) <input type="checkbox"/> Staved lumber core (SLC) <input type="checkbox"/> Particle board (normally for cheap construction) <input type="checkbox"/> Fire-Resistant composite core (default for fire-rated doors)
	Hollow Core: default for closet doors.
	Louvers at: <input type="checkbox"/> Bottom <input type="checkbox"/> Full panel <input type="checkbox"/> Size as indicated <input type="checkbox"/> None <input type="checkbox"/> Fusible link for fire-rated. Louver material: <input type="checkbox"/> Galvanized steel <input type="checkbox"/> Clear anodized <input type="checkbox"/> Color anodized. <input type="checkbox"/> Wood, matching door face
<input type="checkbox"/> Closet Bi-fold Doors. <input type="checkbox"/> Closet sliding Doors. <input type="checkbox"/> Sliding barn doors <input type="checkbox"/> Pocket Sliding Doors. <input type="checkbox"/> Lead lined doors.	
Glazing: <input type="checkbox"/> Vision glazing. <input type="checkbox"/> Full glazing. <input type="checkbox"/> None <input type="checkbox"/> Safety glazing for fire-rated. (wire glass is not allowed)	
Frame: <input type="checkbox"/> Hollow Metal <input type="checkbox"/> Wood <input type="checkbox"/> Aluminum	
Stile and Rail Doors – 081433 (08212) (swinging) <input type="checkbox"/> Exterior (no warranty) <input type="checkbox"/> Interior (lifetime-warranty)	Manufacturers: <input type="checkbox"/> Masonite (Marshfield-Algoma) <input type="checkbox"/> Eggers Industries (VT industries) <input type="checkbox"/> Haley Brothers <input type="checkbox"/> Other: _____
Fire-rated: <input type="checkbox"/> 20 min. <input type="checkbox"/> 40 min <input type="checkbox"/> 60 min <input type="checkbox"/> Non fire rated	
Glazing: <input type="checkbox"/> Vision glazing. <input type="checkbox"/> Full glazing. <input type="checkbox"/> Half <input type="checkbox"/> None	

	<input type="checkbox"/> Safety glazing for fire-rated. (wire glass is not allowed) Louvers at: <input type="checkbox"/> Bottom <input type="checkbox"/> Full panel <input type="checkbox"/> Size as indicated <input type="checkbox"/> None <input type="checkbox"/> Fusible link for fire-rated. Construction: <input type="checkbox"/> Stile and Rail <input type="checkbox"/> Raised-Panel <input type="checkbox"/> Flat-Panel Face: <input type="checkbox"/> Plastic Laminate Veneers: <input type="checkbox"/> plain sliced white maple <input type="checkbox"/> plain sliced white birch <input type="checkbox"/> medium density overlay (MDO)-field painted. Frame: <input type="checkbox"/> Hollow Metal <input type="checkbox"/> Wood <input type="checkbox"/> Aluminum <input type="checkbox"/> Stile and Rail Doors (sliding): 08263
FRP Doors 08221	<input type="checkbox"/> Fiberglass reinforced plastic doors and frames
Sound-control doors 08346	<input type="checkbox"/> STC: _____
Folding Doors 08351	Wood closet doors: <input type="checkbox"/> Stile and Rail <input type="checkbox"/> Flush
Overhead Doors <input type="checkbox"/> Exterior <input type="checkbox"/> Interior	Overhead Coiling Doors - 083323 (08331) Cornell: <input type="checkbox"/> ESD 10 : rolling service doors. <input type="checkbox"/> ESD 20 : insulated doors. <input type="checkbox"/> ERD 11 : Smokeshield Smoke and fire rated coiling doors. <input type="checkbox"/> ERD 21 : Smokeshield Firemiser insulated fire doors. Options: <input type="checkbox"/> Non-insulated <input type="checkbox"/> Insulated <input type="checkbox"/> Non-rated <input type="checkbox"/> Rated Manual: <input type="checkbox"/> Push-up <input type="checkbox"/> Crank <input type="checkbox"/> Chain <input type="checkbox"/> Motorized Mounting: <input type="checkbox"/> Face of Wall <input type="checkbox"/> Between Jambs ----- Counter Doors 08323 (08331): Cornell: <input type="checkbox"/> ESC 10 : rolling counter doors. <input type="checkbox"/> ESC 20 : rolling counter doors with integral frames. <input type="checkbox"/> ERC 11 : Rolling counter fire door. <input type="checkbox"/> ERC 20 : Rolling counter fire door with integral frame. <input type="checkbox"/> Overhead Door: 650 Series counter doors. Options: <input type="checkbox"/> with integral counter <input type="checkbox"/> without integral counter. <input type="checkbox"/> Non-rated <input type="checkbox"/> Rated Manual: <input type="checkbox"/> Push-up <input type="checkbox"/> Crank <input type="checkbox"/> Chain <input type="checkbox"/> Motorized Mounting: <input type="checkbox"/> Face of Wall <input type="checkbox"/> Between Jambs ----- Overhead Coiling Grilles - 083326 (08334) <input type="checkbox"/> ESG 10 by Cornell: open curtain rolling grilles. <input type="checkbox"/> ERG-IBC by Cornell: CrossingGard emergency Response Grille. Manual: <input type="checkbox"/> Push-up <input type="checkbox"/> Crank <input type="checkbox"/> Chain <input type="checkbox"/> Motorized Mounting: <input type="checkbox"/> Face of Wall <input type="checkbox"/> Between Jambs ----- Overhead Sectional Doors 083613 (08361) * Cornell (cookson) does not make sectional doors. <input type="checkbox"/> Aluminum 511 glazed panels by Overhead Door <input type="checkbox"/> Model 3216, Thermally-Broken Insulated Steel Back by CHI . Glazing: <input type="checkbox"/> Tempered Glass <input type="checkbox"/> Insulated glass (14 feet wide max) <input type="checkbox"/> Plexiglas <input type="checkbox"/> Clear Lexan Operation: <input type="checkbox"/> Pull Rope <input type="checkbox"/> Chain <input type="checkbox"/> Motorized Finish: <input type="checkbox"/> Clear anodized (standard) <input type="checkbox"/> Bronze anodized <input type="checkbox"/> Powdered coated Spring Cycle Duty: <input type="checkbox"/> 10k (standard) <input type="checkbox"/> 25k <input type="checkbox"/> 50k <input type="checkbox"/> 75k <input type="checkbox"/> 100k Finish: <input type="checkbox"/> Factory powdered coated galvanized steel (default). <input type="checkbox"/> Stainless steel. <input type="checkbox"/> Clear anodized aluminum. <input type="checkbox"/> Color anodized aluminum, color: _____

Access Doors and Frames - 083113 (08311) <input type="checkbox"/> Exterior <input type="checkbox"/> Interior	<input type="checkbox"/> Fire-rated <input type="checkbox"/> Non-fire-rated. <input type="checkbox"/> Walls. <input type="checkbox"/> Ceilings. <input type="checkbox"/> Insulated. <input type="checkbox"/> Non-insulated. <input type="checkbox"/> Exposed flange. <input type="checkbox"/> Flange covered with joint compound for gypsum wall. <input type="checkbox"/> Field painted, factory primed steel. (default) <input type="checkbox"/> Stainless steel.
Smoke seal system for elevator lobbies	Plastic 083493 (07870): <input type="checkbox"/> SmokeGuard Metal Door 08301: <input type="checkbox"/> Total Door System
Door Hardware – 087100 (08710)	Hardware Consultant: Send floor plans and door schedule, particular finish. Electrical Consultant: Coordinate for electrical requirements below. <input type="checkbox"/> Low energy door operators (accessible push button type for regular doors) <input type="checkbox"/> Magnetic door holders
Automatic Door Operators 087113 (08716)	Doors are not supplied, only operators. This section can be combined with 087100 – Part of Hardware Set by Door Hardware Consultant. – Indicate this on Door Schedule. <input type="checkbox"/> Low energy door operators (accessible push button type)
Fences and Gates	See Coordination - Exterior.
Operable Panel Partitions - 102226 (10651)	<input type="checkbox"/> Paired panel Model #632 by Hufcor . <input type="checkbox"/> Paired panel Series 6500 by Hufcor . <input type="checkbox"/> Alpha Series by Advanced Equipment Corp. <input type="checkbox"/> Classic Elite by Skyfold . Type: <input type="checkbox"/> Manual. <input type="checkbox"/> Electrically operated. STC Rating: _____ Pocket doors: <input type="checkbox"/> Pocket Door is by others (partition manufacturers don't make them) <input type="checkbox"/> None.
ICU/CCU Doors 084243 (08343)	Manual <input type="checkbox"/> Sliding <input type="checkbox"/> Swinging Finish: <input type="checkbox"/> Match storefront or windows system finish. <input type="checkbox"/> Other: _____

PAINTING

<p>Paint (best to select colors from one manufacturer)</p>	<p><input type="checkbox"/> Dunn-Edwards. <input type="checkbox"/> Sherwin Williams. <input type="checkbox"/> PPG <input type="checkbox"/> Kelly-Moore. <input type="checkbox"/> Vista Paint. <input type="checkbox"/> Benjamin-Moore <input type="checkbox"/> Other: _____</p>
<p>Exterior Paint - 099100 (09910)</p>	<p>CMU: <input type="checkbox"/> Semi-gloss Concrete: <input type="checkbox"/> Semi-gloss Portland Cement Plaster: <input type="checkbox"/> Standard latex paint <input type="checkbox"/> Elastomeric paint: Tnemec 156 Enviro-Crete by Tnemec. Gloss: <input type="checkbox"/> Flat <input type="checkbox"/> Semi-gloss Metal: <input type="checkbox"/> Semi-gloss <input type="checkbox"/> Gloss Wood: <input type="checkbox"/> Painted. <input type="checkbox"/> Stained and clear finish <input type="checkbox"/> Clear finish.</p>
<p>Interior Paint - 099100 (09910)</p>	<p>CMU: <input type="checkbox"/> Semi-gloss Concrete: <input type="checkbox"/> Semi-gloss Metal: <input type="checkbox"/> Semi-gloss <input type="checkbox"/> Gloss Gypsum Board: Ceiling: <input type="checkbox"/> Semi-gloss <input type="checkbox"/> Eggshell <input type="checkbox"/> Flat Walls: <input type="checkbox"/> Semi-gloss <input type="checkbox"/> Eggshell Gypsum Veneer: <input type="checkbox"/> Semi-gloss <input type="checkbox"/> Flat Glass-Reinforced Gypsum(GRG): <input type="checkbox"/> Semi-gloss <input type="checkbox"/> Flat Wood: <input type="checkbox"/> Painted. <input type="checkbox"/> Stained and clear finish <input type="checkbox"/> Clear finish.</p>
<p>High Performance Coatings - Field painted - 099600 (09960)</p>	<p>Need to indicate on drawing where high performance paint vs regular paint will be applied. Plaster: See Exterior Paint above. Metals: <input type="checkbox"/> Gypsum board (Epoxy): 113 by Tnemec. <input type="checkbox"/> CMU walls (Epoxy): Stoneglaze by Stonhard. <input type="checkbox"/> Galvanized and Ferrous Metal Finish: Aliphatic Acrylic Urethane (Semi-gloss finish) <input type="checkbox"/> Metallic Finish: Endura-Shield 1077, spray-applied by Tnemec. <input type="checkbox"/> Non-Metallic Finish: Endura-Shield 1075 by Tnemec.</p>
<p>Factory Finishes - specified in each section (Some common options, check with manufacturers)</p>	<p>Steel: <input type="checkbox"/> Factory primer only for field finish. <input type="checkbox"/> Powdered coated. <input type="checkbox"/> Enamel. Galvanized Steel: <input type="checkbox"/> Hot-dipped galvanized. <input type="checkbox"/> Zinc coated. Aluminum: Kynar (fluoropolymer): <input type="checkbox"/> 2 coat (primer & finish) <input type="checkbox"/> 3 coat (add clear coat) Anodized: <input type="checkbox"/> Clear anodized <input type="checkbox"/> Colored anodized, color:</p>
<p>Anti-Graffiti Coating System - 099623 (09966)</p>	<p>Non-sacrificial Anti-Graffiti Coating System: Clear Urethane based system: Textured Coatings of America. <input type="checkbox"/> Clear <input type="checkbox"/> Opaque.</p>

STAIRS/ELEVATORS

Identify a stair number when more than one stair exists for a project. (Do the same for elevators)

Huge Disclaimer: Elevators/Lifts are specialized equipment that is beyond my expertise. Please contact your favorite manufacturer and seek help with specs and drawing details. Do not design them in a vacuum (you will have change orders). Have the elevator rep edit their standard spec for your project. I can't edit their spec (again, you will have change orders if you have me edit).

<p>Metal Fabrication 055000 (05500)</p>	<p>Bollards: <input type="checkbox"/> Fixed, utility type, steel tube with concrete fill. <input type="checkbox"/> Removable bollards. Extruded Abrasive Metal Nosings (at stairs): <input type="checkbox"/> Type 24 by American Safety Tread <input type="checkbox"/> Type 24 Spectra by Wooster Products Inc.</p>
<p>Cast-In-Place Concrete - 033000 (03300)</p>	<p><input type="checkbox"/> Concrete stairs - Coordinate with structural.</p>
<p>Metal Stairs - 055100 (05511) <input type="checkbox"/> Exterior. <input type="checkbox"/> Interior.</p>	<p><input type="checkbox"/> Site fabricated. <input type="checkbox"/> Railing as indicated on Drawings. <input type="checkbox"/> Field poured concrete treads (concrete filled metal pan).</p>
<p>Prefabricated Steel Stair System - 055112 (05512) <input type="checkbox"/> Exterior. <input type="checkbox"/> Interior.</p>	<p><input type="checkbox"/> Coordinate with structural for landing attachment to structure. <input type="checkbox"/> American Stairs (Basis of Design). Sharon Stair is equal. <input type="checkbox"/> Picket (default) <input type="checkbox"/> Multiple (5) strand round design. <input type="checkbox"/> Field poured concrete treads. <input type="checkbox"/> Abrasive nosing. (05500) <input type="checkbox"/> Field painted. (09910)</p>
<p>Pipe and Tube Railings - 055213 (05521) <input type="checkbox"/> Exterior. <input type="checkbox"/> Interior.</p>	<p><input type="checkbox"/> Interior: Field painted steel. <input type="checkbox"/> Exterior: Field painted galvanized steel. <input type="checkbox"/> Stainless steel used for : Wing wall for drinking fountains <input type="checkbox"/> in this section. <input type="checkbox"/> Toilet Accessories Section 102800 (10801) ready-made wing-wall from stainless-steel grab bars. <input type="checkbox"/> Wing wall for automatic entrance doors. <input type="checkbox"/> Wing wall below relocatable HVAC unit.</p>
<p>Ornamental Railings - 057300 (05721) <input type="checkbox"/> Exterior. <input type="checkbox"/> Interior.</p>	<p><input type="checkbox"/> Standard catalog items by Julius Blum. Railing: <input type="checkbox"/> Factory finished steel <input type="checkbox"/> Factory prime, field finished steel <input type="checkbox"/> Stainless steel <input type="checkbox"/> Aluminum -clear anodized. <input type="checkbox"/> Bronze Options: <input type="checkbox"/> Glass infill. <input type="checkbox"/> Wood handrail cap <input type="checkbox"/> Wrought iron railings <input type="checkbox"/> Stainless steel inset.</p>
<p>Ladders <input type="checkbox"/> Exterior. <input type="checkbox"/> Interior.</p>	<p><input type="checkbox"/> Field painted steel. Galvanized steel at exterior – 055000 (05500) <input type="checkbox"/> Aluminum ladders - 055134 (05501) by Alaco. <input type="checkbox"/> Other: _____</p>
<p>Hydraulic Elevators - 142400 (14240) (Get help from Elevator Rep.)</p>	<p>Indicated the following on the Drawings: <input type="checkbox"/> Number of stops. <input type="checkbox"/> Total travel height. <input type="checkbox"/> Size. <input type="checkbox"/> Custom call buttons. <input type="checkbox"/> Light fixtures. Basis of Design: <input type="checkbox"/> Kone <input type="checkbox"/> Otis <input type="checkbox"/> ThyssenKrupp <input type="checkbox"/> Schindler <input type="checkbox"/> Republic (Non-proprietary) in Goleta. Elevator consultant: <input type="checkbox"/> Lerch Bates For Otis Elevators: <input type="checkbox"/> Travel under 20 feet: Holeless Hydraulic Elevator. <input type="checkbox"/> Travel from 15 to 44 feet 1 inch: Telescopic Holeless Hydraulic Elevator. <input type="checkbox"/> Travel from 26 to 60 feet: Roped Holeless Hydraulic Elevator—where existing conditions include waterfront, hard-to-drill substrate, hazardous in-ground material or other conditions that make it expensive to drill well holes. <input type="checkbox"/> Travel from 15 to 60 feet: Holed Hydraulic Elevator – where it is cost effective to drill well holes. <input type="checkbox"/> Travel from 50 to 300 feet: Gen2 Machine Room-less System by Otis.</p>
<p>Electric Traction Elevators - 142100 (14210)</p>	<p><input type="checkbox"/> EcoSpace, gearless system by Kone. <input type="checkbox"/> Travel over 120 feet: Elevonic High-Rise Gearless System.</p>

Stairway Chairlifts - 144119	Stair lift for straight stairways: <input type="checkbox"/> XPRESS II by Garaventa . Other: ____
Wheelchair Lifts – 144200 (14420) <input type="checkbox"/> Interior <input type="checkbox"/> Exterior	<input type="checkbox"/> Acme screw lift: CDE 2 gate by National Wheel-O-Vator/ThyssenKrupp. <input type="checkbox"/> Porch lift Model PL-EZE (enclosure) by Access/ThyssenKrupp. <input type="checkbox"/> PL-S by Access/ThyssenKrupp. Indicated the following on the Drawings: <input type="checkbox"/> Number of stops. <input type="checkbox"/> Total travel height. <input type="checkbox"/> Platform size. Configuration: <input type="checkbox"/> Straight-thru <input type="checkbox"/> 90 degree exit <input type="checkbox"/> Both. <input type="checkbox"/> National Wheel-O-Vator/ThyssenKrupp <input type="checkbox"/> Access/ThyssenKrupp

TOILET ACCESSORIES - 102800 (10801)
B-Bobrick Model Number (W x H x D)

- A. Coordinate with Owner if toilet accessories will be Owner Furnished Owner Install (OFOI) or Owner Furnished Contractor Install (OFCI). Some jurisdiction requires showing at least the accessible accessories to check for compliance.
- B. Get accessories pre-approved by client on each project, unless it's another project with same client and we're using exactly the same accessories.
- C. Accessories Schedule should be indicated on Drawings. Identify where each model will be located, showing height requirements. Spec section will cross-reference drawings.
- D. Spec section will not repeat the model numbers. You may revised/delete/add items as needed without affecting specs.
- E. Bobrick Series Names: (Price Index)
 - 1. Stainless steel: Contra (1.8), Trimline (1.5), and Classic (1.0).
 - 2. Plastic: Matrix (0.6)
- F. Toilet tissue dispensers in accessible toilet compartment shall be recessed, or semi-recessed so as not to project more than 3 inches from face of wall per DSA Policy 99-07.
- G. Indicate items that will be OFCI or OFOI.

Here are some model numbers you can use:

	Surface Mount	Recess Mount
Toilet Seat Cover Dispenser	<input type="checkbox"/> Surface Mount: Classic B-221 , Dispense 250 (15-3/4 x 11 x 2) <input type="checkbox"/> Surface Mount: Contura B-4221 .	<input type="checkbox"/> Recessed: Classic B-301 , Dispense 500 (15-5/8 x 11 x 2-5/8) \$60. <input type="checkbox"/> Recessed: Classic B-3013 , Dispense 500 (15-5/8 x 11-1/4) \$150
Toilet Tissue Dispenser	<input type="checkbox"/> Surface Mount: Contura B-4288 . <input type="checkbox"/> Surface Mount: Single-roll B-66997 , Satin finish. <input type="checkbox"/> Surface Mount: Classic B-2888 , holds two rolls.	<input type="checkbox"/> Semi-Recessed: Classic Multi-roll B-3888 (6-1/16 x 11-1/16 x 3-3/16, project out 2-3/4) <input type="checkbox"/> Semi-Recessed: Classic Single-roll B-6677 (5 1/2" W x 5 1/4" H x 3 3/8" min. depth)
Toilet Seat Cover and Tissue Dispenser Combo	<input type="checkbox"/> Partition Mount: B-3471 . <input type="checkbox"/> Surface Mount: B-3479 .	<input type="checkbox"/> Recessed Mount: Classic B-3474 .
Toilet Seat Cover and Tissue Dispenser Sanitary Napkin Disposal Combo		<input type="checkbox"/> Recessed Mount: Classic B-3571 .
Paper Towel Dispenser	<input type="checkbox"/> Surface Mount: Classic B-262 (10-3/4 x 14 x 4) <input type="checkbox"/> Surface Mount: Classic B-2620 , similar to B-262 , but with knob-latch.	<input type="checkbox"/>
Touchless Paper Towel Dispenser	Georgia Pacific enMotion : <input type="checkbox"/> Surface Mount <input type="checkbox"/>	Recessed Mount <input type="checkbox"/> Stainless steel <input type="checkbox"/> Plastic
Paper Towel Dispenser/Waste Receptacle Combo	<input type="checkbox"/>	<input type="checkbox"/> Recessed: Classic B-369 <input type="checkbox"/> Recessed: Classic B-3944 <input type="checkbox"/> Semi-Recessed: Classic B-3961 (15-5/16 x 54-1/8 x 4-1/8)
Waste Receptacle - Wall Mount	<input type="checkbox"/> Surface Mount: Classic B-275 .	<input type="checkbox"/> Semi-Recessed: Classic B-3644 (15-5/16 x 28-3/4 x 4) <input type="checkbox"/> Contura B-43644
Waste Receptacle – Floor Mount	<input type="checkbox"/> B-2250 with cover <input type="checkbox"/> B-2260 Open-top, No Cover <input type="checkbox"/> B-2280 Open-top, No Cover	<input type="checkbox"/>

Counter Under-mount	<input type="checkbox"/> Circular Waste Chute B-529	
Sanitary Napkin Vendor	<input type="checkbox"/> Surface Mount: Classic B-352 (12-1/2 x 26-3/8 x 4 to 6-3/8) <input type="checkbox"/> Surface Mount: Trimline B-2800 (14-7/8 x 25-3/8 x 4-3/4)	<input type="checkbox"/>
Sanitary Napkin Disposal	<input type="checkbox"/> Surface Mount: Classic B-254 (10-11/16 x 15-1/8 x 4-1/16) <input type="checkbox"/> Surface Mount: Contra B-270 . <input type="checkbox"/> Partition Mount: Classic B-354 .	<input type="checkbox"/> Recessed: Contura B-4353 . <input type="checkbox"/> Recessed: Classic B-353 .
Soap dispenser	<input type="checkbox"/> Surface Mount: Classic B-132 (4-13/16 x 8-1/8 x 3-7/8) \$45. <input type="checkbox"/> Surface Mount: Classic B-2111 (8 1/8 x 4 3/4 x 3 1/2) vertical \$30. <input type="checkbox"/> Surface Mount: Classic B-2112 (horizontal) <input type="checkbox"/> Surface Mount: Contura B-4112 . \$44.	<input type="checkbox"/> Recessed: Contura B-4063 .
Framed Mirror	<input type="checkbox"/> B-290 (Pick one of the standard sizes, 30 x 42 is not standard)	
Framed Mirror w/ Shelf	<input type="checkbox"/> B-292 same as 290 but with shelf	
Channel Framed Mirror w/ Shelf	<input type="checkbox"/> B-166	
Channel Framed Mirror	<input type="checkbox"/> B-165	
Grab Bar	<input type="checkbox"/> Straight, 1-1/4 diameter, B-5806 (12, 18, 24, 30, 36, 42, 48), concealed with flange mount. <input type="checkbox"/> Straight, 1-1/2 diameter, B-6106 (18 to 48), exposed mount. <input type="checkbox"/> Straight, 1-1/2 diameter, B-6806 (18 to 48), concealed with flange mount. <input type="checkbox"/> Straight, 1-1/2 diameter, B-6806.99 (18 to 48), concealed with flange mount with satin, peened nonslip gripping surface. <input type="checkbox"/> L shape, Wheelchair Toilet Compartment, B-5837 (36 x 54) <input type="checkbox"/> L shape, Tub/Shower/Toilet, B-58616 (32 x 28) <input type="checkbox"/> L shape, Tub/Shower/Toilet, B-6861. <input type="checkbox"/> Drinking Fountain Wing Wall: 3800 Series, Type 75 by ASI.	
Diaper Changing Station	<input type="checkbox"/> Surface: Bobrick/Koala Kare KB110-SSWM .	<input type="checkbox"/> Semi-Recessed: B-2210 (30-3/4 x 18-3/4 x 2-1/2)

		<input type="checkbox"/> Recessed: Bobrick/Koala Kare KB100-00ST .
Robe Hook	<input type="checkbox"/> B-7671 Bright polished, Single (2 by 2 flange, project out 1-5/8). <input type="checkbox"/> B-76717 Satin-finish.	
Hat and Coat Hook	<input type="checkbox"/> B-682 Bright polished. <input type="checkbox"/> B-6827 Satin finish.	
Electric Hand Dryer	<input type="checkbox"/> Push button activation: Model A by World Dryer . <input type="checkbox"/> Motion activation: Model XA5 by World Dryer.	<input type="checkbox"/> Motion activation: Bobrick B-750 .
Mop and Broom Holder	<input type="checkbox"/> B-223 x 24, 3 Holder (24 inches) <input type="checkbox"/> B-223 x 36, 4 Holder (36 inches)	
Shower Soap Dish		<input type="checkbox"/> Recessed: B-4390 .
Folding Shower Seat	<input type="checkbox"/> B-5181 Reversible Solid Phenolic (33 x project out 22-5/16) <input type="checkbox"/> B-5191 Shower Seat Solid Phenolic (18 x project out 15-13/16) <input type="checkbox"/> B-517 Padded Shower Seat. <input type="checkbox"/> Bradley-9569 Reversible Solid Phenolic (34-1/2 x project out 22) good for 36 inch minimum requirements of UBC Figure 11B-2A Roll-In Shower.	
ADA Accessible Signage	<input type="checkbox"/> Section 10431	
By Plumbing consultant	<input type="checkbox"/> Hi/Lo Drinking Fountain, Vanity, Toilet, Urinal, Faucets	

SPECIAL CONSTRUCTION

Cold Storage Rooms	<input type="checkbox"/> by food service equipment consultant Installation: <input type="checkbox"/> Outdoor <input type="checkbox"/> Indoor Type: <input type="checkbox"/> Freezer <input type="checkbox"/> Refrigerator Manufacturer: _____
Food Service Equipment – 114000 (11400)	<input type="checkbox"/> As listed on Drawings (by food service equipment consultant)
Appliances – 113100 (11451)	Cooktop: <input type="checkbox"/> Electric <input type="checkbox"/> Gas Oven: <input type="checkbox"/> Electric <input type="checkbox"/> Gas <input type="checkbox"/> Exhaust Hood <input type="checkbox"/> Refrigerator <input type="checkbox"/> Freezer <input type="checkbox"/> Dishwasher <input type="checkbox"/> Microwave Oven
Pre-Engineered buildings - 133500	Pre-engineered (metal) building systems: Structural steel framing system. Metal roof system. Metal trim. Basis of Design: <input type="checkbox"/> Butler
Modular Class Room Buildings (relocatables) – Not a section but scope of work	<input type="checkbox"/> Relocate existing modular class room buildings. <input type="checkbox"/> Refurbish existing modular class room buildings. <input type="checkbox"/> _____

DIVISION 1 SECTIONS

Mock-ups	List: Project management and Coordination - 013100 (01310). Conduct progress meetings at intervals of: <input type="checkbox"/> Weekly <input type="checkbox"/> Bi-Weekly <input type="checkbox"/> Monthly <input type="checkbox"/> Regular.
Submittals	Submittal Procedures - 013300 (01330) Process Time: 21 days. Architect will request for more time if needed. Shop Drawings: <input type="checkbox"/> 1 set of reproducible Mylars and 3 sets of prints. <input type="checkbox"/> 4 sets of prints (no Mylars). (No one uses Mylars any more)
Temp Utilities	
Temp field office (trailer)	Temporary Facilities and Controls - 015000 (01500) <input type="checkbox"/> Trailer and office supplies.
Warranty starts	<input type="checkbox"/> at Substantial Completion <input type="checkbox"/> Other: _____
Contractor Working Hours	Summary - 011000 (01100) <input type="checkbox"/> 8 am - 5 pm <input type="checkbox"/> per General Conditions <input type="checkbox"/> per Supplementary Conditions.
Temporary Facilities	Temporary Facilities and Controls - 015000 (01500) <input type="checkbox"/> Usage paid and provided for by: <input type="checkbox"/> Use existing at no cost to contractor. Sewer Service: <input type="checkbox"/> Contractor <input type="checkbox"/> Owner <input type="checkbox"/> Owner but will be billed. Water Service: <input type="checkbox"/> Contractor <input type="checkbox"/> Owner <input type="checkbox"/> Owner but will be billed. Sanitary Facilities: <input type="checkbox"/> Contractor <input type="checkbox"/> Owner <input type="checkbox"/> Owner but will be billed. <input type="checkbox"/> Portable Chain-Link Fencing. (nothing fancy; whatever contractor has) <input type="checkbox"/> Wind Screen Fabric: Green. (added cost)
Lock Preference	Schlage: <input type="checkbox"/> Primus <input type="checkbox"/> Generic. Sargent: <input type="checkbox"/> Primus <input type="checkbox"/> Generic.
Toilet Accessories	<input type="checkbox"/> Get accessories pre-approved by client on each project, unless it's another project with same client and we're using exactly the same accessories.
Temporary Trailer (cost money. See if you can use existing space for meetings)	<input type="checkbox"/> Need it <input type="checkbox"/> Not need it <input type="checkbox"/> Use existing structure, location to be determined. Used by: <input type="checkbox"/> IOR <input type="checkbox"/> CM <input type="checkbox"/> Architect <input type="checkbox"/> Owner Equipment in Temp Trailer – List below: <input type="checkbox"/> See General Conditions (With the current use of cell phones, equipment has become less important) <input type="checkbox"/> Conference Desk (1)/ chairs (10 minimum). <input type="checkbox"/> Filing cabinet. <input type="checkbox"/> Phone. <input type="checkbox"/> Computer. <input type="checkbox"/> Cable/DSL broadband Internet connection. <input type="checkbox"/> Water service. <input type="checkbox"/> Other: _____

THEATER PROJECTS

DIVISION 6 - WOOD AND PLASTICS

06401 Architectural Woodwork - new or refurbish/restoration

DIVISION 8 - DOORS AND WINDOWS

08346 Sound-Control Door Assemblies

DIVISION 9 – FINISHES

09000 Sound Absorptive Acoustical Finish System

09210 Gypsum Plaster

09215 Gypsum Veneer Plaster

09645 Stage-Floor Assemblies - new or refurbish

DIVISION 11 – EQUIPMENT

11066 Rigging - by AV consultant

11525 Projection Screen - by AV consultant

DIVISION 12 - FURNISHINGS

12710 Theater Seating – new or refurbish

GREENHOUSE

Basis of Design	<input type="checkbox"/> Winandy Greenhouse Company 2211 Peacock Road Richmond Indiana (765) 935-2111 http://www.winandygreenhouse.com <input type="checkbox"/> Other _____
Style	<input type="checkbox"/> Free-standing <input type="checkbox"/> Gable Connect <input type="checkbox"/> Lean-to <input type="checkbox"/> Gutter Connected
Greenhouse Skin	Glass (pane): <input type="checkbox"/> Single <input type="checkbox"/> Double <input type="checkbox"/> Triple. <input type="checkbox"/> Polycarbonate panels: 8mm 16mm (5/8") Corrugated <input type="checkbox"/> Acrylic panels: 8mm 16mm (5/8") Corrugated <input type="checkbox"/> Other _____
Side Wall Design Operator:	<input type="checkbox"/> Manual <input type="checkbox"/> Motorized
Roof Ventilators	<input type="checkbox"/> None <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> Other _____
Screens	<input type="checkbox"/> Yes <input type="checkbox"/> No
Heating	<input type="checkbox"/> gas unit heaters <input type="checkbox"/> oil unit heaters <input type="checkbox"/> hydronic heating <input type="checkbox"/> electric heaters
Growth light	<input type="checkbox"/> Yes <input type="checkbox"/> No
Shade/energy curtains	<input type="checkbox"/> Yes <input type="checkbox"/> No
Fire retardant	<input type="checkbox"/> Yes <input type="checkbox"/> No
Controls	<input type="checkbox"/> none <input type="checkbox"/> computer interface <input type="checkbox"/> weather station and computer interface <input type="checkbox"/> weather station

REHABILITATION OF HISTORIC BUILDINGS

	02071 Selective Historical Demolition
	03450 Glass Fiber Reinforced Cement (GFRC)
	Masonry Restoration & Cleaning (painted brick masonry)
	Masonry Repair and Repointing
	05511 Metal Restoration & Cleaning (architectural cast iron)
	06401 Architectural Woodwork Restoration
	07601 Sheet Metal Restoration & Cleaning (architectural sheet metal)
	08701 Finish Hardware Restoration & Cleaning
	09900 Painting

END